

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/2013/W2/1197

Dated: 14/11/13

FIRE SAFETY CERTIFICATE

Certified that the **Sanjha Chulha Restaurant Pvt. Ltd.** located at **361, Kohat Enclave, Pitam Pura, New Delhi – 110034** comprised of Basement, Ground plus Three Upper Floors was issued FSC vide letter no. F.6/DFS/MS/EH/2009/1971 dated 06-09-2009. The premises was re inspected by the officer concerned of this department on 21-10-2013 in the presence of Mr. Pawan Sharma (Managing Director) and found that the said Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D of Sub Division-D 5 with effect from 14/11/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on14/11/13... at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. Pawan Sharma (Managing Director)
Sanjha Chulha Restaurant Pvt. Ltd.,
361, Kohat Enclave, Pitam Pura, New Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Swaha Chulha Restaurant Pvt. Ltd.
361, Kohat Enclave, Pitam Pura, New Delhi-39
2. Type of Occupancy : Assembly Basement + Ground + 3 upper floors
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DPS/MS/CH/2009/1971 dated 06/07/09
5. Fire Safety directives Letter No. : -----
6. Date of inspection : 21-10-13
7. Name of the Inspecting Officer : Mukesh Verma ADD(MN)
8. Name and designation of Officer Pawan Sharma
 from the building side : (Managing Director)
9. Year of Construction : 1989
10. Applicant's letter No. : Nil Dated 30-9-13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	Provided	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	Old case	Old case	Old case
	• Basements	Old case	Old case	Old case
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old case	Old case	Old case

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	8	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Yes	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR

NA
/m

11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump 			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head		N/A	
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Staring/Manual stopping			
	➤ Pump House Access			
	<ul style="list-style-type: none"> • Terrace level 	225 lpm 450 lpm	Provided	MR
	➤ Discharge of pump	40 m	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity 	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	5000 lts	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 		N/A	
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 		N/A	
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required at LPG bank	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

Signature of the Inspecting Officer *[Signature]* 7/11/13

Name *Mukesh Verma*

Designation *ADO (MM)*

DO (Inest) dm

Signature of the Inspecting Officer

Name

Designation

