

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: cfohq.dlfire@nic.in, Tel:- 011-23414000

No. F6/MS/DFS/EH/2013/ 52 / 1194

Dated 13 / 11 / 13

FIRE SAFETY CERTIFICATE

Certified that the M/s Pollo Tropical located at M-A01, Ground Floor, DLF Place, Saket, New Delhi-110017, comprised of 02 Basements, Ground Floor + Two Upper Floors. The restaurant is running in ground floor only with seating capacity of 94 persons. The premises was inspected by the officer concerned of this department on 27/09/2013 in the presence of Mr. Anuj, Manager and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group - D, Assembly Building(Restaurant) with effect from ~~13-11-13~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~13/11/13~~ at New Delhi by.



(Dr. G.C. Misra)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

- (1) Dy. Health Officer,
MCD, South Zone,
Green Park, New Delhi.
- (3) M/s Pollo Tropical
M-A01, Ground Floor, DLF Place,
Saket, New Delhi-110017

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in, any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- M/s Pollo Tropical, M-A01, Ground Floor, DLF Place, Saket, New Delhi-110017
2. Type of occupancy:- Assembly Building, Group – D, Restaurant
3. Type of case:- New Case
4. Details of previous NOC:- Nil
5. Fire safety directives No.- Nil
6. Date of inspection:-27 /09/2013
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr.Anuj, Manager
9. Year of construction:- 2010.
10. Applicant's letter No:-Nil dated 03/07/13, Two Basements, Ground floor + Two Upper floors Restaurant is running in Ground floor

S.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	Provided 10.5 mtrs	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	06 m	Provided	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	One	Provided by mall	MR
	E. Width of corridor			
	F. Door size	2 mtrs	Two Exits 2 m & 1.40 m	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided by Mall	MR
	2) Sealing of electrical shafts	Required	Provided by Mall	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	05 Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	Provided by mall	MR
	2) Length of hose reel hose	30 m	Provided by mall	MR
	3) Nozzle diameter	5 mm	Provided by mall	MR
7.	Automatic Fire Detection & Alarming System	Provided and maintained by Mall		
	1) Type of detectors	do	do	do
	2) Location of main panel	do	do	do
	3) Location of repeater panel	do	do	do
	4) Alternate source of power	do	do	do
	5) Hooter's Location	do	do	do
8.	MOEFA	Provided and maintained by Mall		
9.	Public Address System	Provided and maintained by Mall		
10.	Automatic Sprinkler System	Provided and maintained by Mall		
	1) Basement	do	do	do
	2) Upper floors	do	do	do
	3) Sprinkler above false ceiling	do	do	do
11.	Internal Hydrants	Provided and maintained by Mall		
	1) Size of riser/down-comer	do	do	do
	2) Number of hydrants per floor	do	do	do
	3) Hose box	do	do	do
12.	Yard Hydrants	Provided and maintained by Mall		
	1) Total number of hydrants	do	do	do
	2) Hose box	do	do	do
13.	Pumping Arrangement	Provided and maintained by Mall		
	1) Ground level	do	do	do
	a) Discharge of main pump	do	do	do
	b) Head of main pump	do	do	do
	c) Number of main pump	do	do	do
	d) Jockey pump out put	do	do	do
	e) Jockey pump head	do	do	do
	f) Stand by pump output	do	do	do
	g) Stand by pump head	do	do	do
	h) Auto starting/Manual stopping	do	do	do
	2) Terrace level	do	do	do
	a) Discharge of pump	do	do	do
	b) Head of pump	do	do	do
	c) Power supply	do	do	do
	d) Auto starting of pump	do	do	do
14.	Captive Water Storage for Fire Fighting	Provided and maintained by Mall		
	1) Under ground tank capacity	do	do	do
	a) Draw-off connection	do	do	do
	b) Fire service inlet	do	do	do
	c) Access to tank	do	do	do
	d) Over head tank capacity	do	do	do
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Provided and maintained by Mall		
	a) Pressurization of lift shaft	do	do	do
	b) Pressurization of lift lobby	do	do	do
	c) Communication in lift car	do	do	do
	d) Fireman's switch	do	do	do
	e) Lift signage	do	do	

N/3

17.	Stand by Power Supply	Provided and maintained by Mall		
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19.	Fire Control Room	Provided and maintained by Mall		
	a) Detector system panel	do	do	do
	b) Flow switch panel	do	do	do
	c) PA system panel	do	do	do
	d) Battery backup	do	do	do
	e) Building floor plan	do	do	do
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A		N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

[Handwritten Signature]
30/11/2013

Name :- D.B. Mukherjee.
Designation :- Assistant Divisional Officer.



DO (South)

[Handwritten Signature]
11/11/13