

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

Fax: 23412593, E-mail:cfhq.dfire@nic.in

No. FC/DFS/MS/School/2013/ND2/1202

Dated: 14/11/13

FIRE SAFETY CERTIFICATE

Certified that the New Priyadarshany Arya Public School at B-171, Gali No-2, Prem Vihar, Karawal Nagar, Delhi-93. Comprised of ground plus two upper floors owned/occupied by New Priyadarshany Arya Public School have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 21/10/13 in the presence of Mr. Brijesh Sharma, Manager, of the school and that the building is fit for occupancy class 'B' Educational Building' with effect from 14/11/13. for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 14/11/13 at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph.23414333

To,

The Manager,
New Priyadarshany Arya Public School,
B-171, Gali No-2, Prem Vihar,
Karawal Nagar, Delhi-93

by o/c

Copy:-

1. The Dy. Director of Education
B-Block, Yumna Vihar,
Delhi-110053

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : New Priyadarshany Arya Public School, B-171,
Gali No-2, Prem Vihar, Karawal Nagar, Delhi -110094
2. Building is comprised of : Ground Plus two upper floor only
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : NBC. Part-IV
7. Date of Inspection : 21/10/2013
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer:
from the building side : Mr. Brijesh Sharma (Manager)
10. Year of Construction : 2006
11. Applicant's letter No : NPDA/04/2013 Dated 09/09/2013

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC/BBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	03 mtr.	03 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 Nos.	01 Nos.	MR
	• Upper Floor	01 Nos.	01 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases	1.50 mtr.	1.50 mtr	MR
	• Upper Floor	1.50 mtr.	1.50 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 mtr.	1.60 mtr.	MR
	f. Door Size	1.0 Mtr.	1.02 mtr.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

New Priyadarshany Arya Public School, B-171, Gali No-2, Prem Vihar, Karawal Nagar, Delhi -94


4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 nos.	06 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 Lpm.	450 Lpm.	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Electricity	MR
	➤ Auto Starting of pump	Required	Provided	MR

IRN-5

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.



DO (ED)

Signature of the Inspecting Officer

Submitted for approval please.

Name Vijay Bahadur
Designation ADO

Dy CFO (N/PZ)