

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

Ph.23414333,Fax:23412593,E-mail:cfohq.dlfire@nic.in

No. FG/DFS/MS/2013/ND2/1220

Dated: 21/11/13

FIRE SAFETY CERTIFICATE

Certified that the D.A.V.Public School (Nursery Wing) at Gate No.2, Main Road, Sreshtha Vihar, Delhi-92, comprised of ground plus one upper floor owned/occupied by D.A.V.Public School have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officer concerned of Fire Service on 06.11.2013 in the presence of Sh. Manoj Kumar (OS), of the school and that the building is fit for occupancy class 'B' 'Educational Building' with effect from 21/11/13 for a period of three years, subject to conditions printed overleaf.

Issued on 21/11/2013 at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

O/C

To,
The Principal
D.A.V.Public School (Nursery Wing)
Gate No.2, Main Road, Sreshtha Vihar, Delhi-92

Copy:-
The Dy.Director of Education
D-Block,Anand Vihar ,Delhi.

4

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

12/11 - 1
INSPECTION REPORT

1. Name & address of the building : D.A.V.Public School(Nursery Wing) at Gate No.2,
Main Road,Sreshtha Vihar,Delhi-92.
1. Building is comprised of : Ground +1 upper floor.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of Previous NOC letter : Nil
5. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11
6. Date of Inspection : 06/11/2013
7. Name of the Inspecting officers : DO Virendra Singh
8. Name and designation of
Officer from the building side : Sh.Manoj Kumar (OS).
9. Year of Construction : 1991
10. Applicant's letter No : letter No.2500-A/13 dated 20/09/2013.

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 Mtrs.	8 Mtrs.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 Nos.	2 Nos.	MR
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M or less	1.10 M each	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01No.	01No.	MR
	g. Width of Corridor	1.5 M	2.40 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
	i. Door in class room	02 Nos.	01 No.	MR/Children's are less than 40
	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

D.A.V.Public School (Nursery Wing) ,Gate No.2,Main Road,Sreshtha Vihar,Delhi-92.

4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 Nos.	15 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	Not Required	Provided	MR
	• Length of hose reel hose	Not Required	30 M	MR
	• Nozzle diameter	Not Required	5 MM	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A

	• Terrace Level			
	➤ Discharge of pump	Not Required	450 LPM Provided	MR
	➤ Head of the Pump	Not Required	40 M	MR
	➤ Power supply	Not Required	Provided	MR
	➤ Auto Starting of pump	Not Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	Not Required	5000 Ltrs.	MR
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.



By CFO (NO 2)

Signature of the Inspecting Officer
 Name **VIRENDRA SINGH**
 Designation **DO (CE)**