

No F 6 / DFS / MS / GH / 2013 / *ND2/1219*

Dated *20/11/13*

FIRE SAFETY CERTIFICATE

Certified that the **Kashvi International Guest house, 8171, Arakashan Road Paharganj, New Delhi – 110055** comprised of Ground floor (reception), 1st floor (03 guest room + 01 Office), 2nd to 4th floor (04 Guest rooms at each floor) total 15 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2010/2018 dated 09-07-2010. The premises was re-inspected by the officer concerned of this department on 28-10-2013 in the presence of Mr. Rahul (Manager) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 15 guest rooms with effect from ~~-----~~ *21/11/13*-2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *21/11/13* at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi – 110049 w.r.t. letter No. 25257/Addl..C.P/Lic(H) dated New Delhi 29/05/2013
2. Kashvi International Guest house,
8171, Arakashan Road Paharganj, New Delhi – 110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

N/12

INSPECTION REPORT

1. Name & address of the building : ~~Hotel~~ Kashvi International, 8171, A. K. Road Pahar Ganj Delhi.
2. Type of Occupancy : Residential (guest House) G+4 Floors ~~G + 4 Floors~~ ^{guest house,} ~~4 + 4 floors.~~ ^{Mudu}
3. Type of Case : RENEWAL
4. Details of previous NOC : F6/DFS/HQ/GH/2010/2018 Dt 09/07/2010
- Fire Safety directives Letter No. : NA
- Date of inspection : 28/10/2013
- Name of the Inspecting Officer : Sh. M.K. Sharma (Assistant Divisional Officer)
- Name and designation of Officer
from the building side : Mr. Rahul (Manager)
- Year of Construction : 2001
10. Applicant's letter No. : letter No. 25257/Addl..C.P/Lic(H) dated New Delhi 29/05/2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	NA	10 mt	MR
	• Gate width	1 Mt	1 Mt	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a.Number of staircases	01	P	MR
	• Upper floors	01	P	MR
	• Basements	NA	NA	NA
	b.Width of staircases			
	• Upper floors	800 MM	1150 MM	MR
	• Basements	NA	NA	NA
	c.Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d.No of continuous staircase to terrace	01	P	MR

Mersle

N/13

	e.Width Of Corridor	1250	2Mt	MR
	f.Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	06	08	MR
	• Types	ABC,Co ₂ , Wco ₂	P	MR
	• IS marking	YES	P	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	P	MR
	• Length of hose reel hose	30	P	MR
	• Nozzle diameter	05	P	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	YES	P	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			

N/14

	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> ○ Ground Level • Discharge of main pump • Head of main pump • Number of main pumps • Jockey pump out put • Jockey pump head • Standby Pump out put • Standby Pump Head • auto Starting/Manual stopping • Pump House Access ○ Terrace level • Discharge of pump • Head of the pump • Power supply • Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	450 LPM	MR
		30 Mt	P	MR
		YES	P	MR
		-	-	-
14	Captive water Storage for fire fighting	NA	NA	NA
	<ul style="list-style-type: none"> • Under ground tank capacity • Draw of connection • Fire service inlet • Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		YES	P	NA
		2500	P	MR
15	Exit Signage	YES	P	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA

meshe

N/15

	<ul style="list-style-type: none"> • Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication in lift Car 	Yes	P	MR
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	Yes	P	MR
	<ul style="list-style-type: none"> • Lift Signage 	Yes	P	MR
17	Standby power supply	NR	P	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC	MR

The fire protection systems provided in the building were tested, checked and found non-functional at the time of inspection.

Keeping in view the non compliance of the minimum standards on Fire prevention and fire Safety required under the rules 35 of the Delhi fire service Rules 2010/ FSC is recommended.

Do (ed) submitted pl. 29-10-13

Signature of the Inspecting Officer

Name :- M.K. Sharma

Designation :- A. D.O. (CC)