

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax: 011-23412593, Email :- cfohq.dlfire@nic.in, Ph:- 011-23414333


No. F6/DFS/MS/School/2013/ 1216.

DATED: 21/11/13

FIRE SAFETY CERTIFICATE

Certified that the Kasturi Devi Public School B-1/60, Vijay Enclave, Gali No.2, Palam Dabri Road New Delhi – 110045, comprised of Ground floor plus one upper floor and school is running at ground floor only owned/occupied by Kasturi Devi Public School. The inspection of school was carried out & found complied with the Fire prevention and Fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 15.10.2013 Fire Service in the presence of Mrs. Rekha (Principal), and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class B “Educational building” for ground floor only with effect from 21/11/13 for a period of three years, subject to condition as mentioned below.

Issued on ... 21/11/2013 ... at New Delhi


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director, (Education), GNCT of Delhi, Old Sectt., New Delhi-54
2. The Principal, Kasturi Devi Public School B-1/60, Vijay Enclave, Gali No.2, Palam Dabri Road New Delhi – 110045

The following fire safety directives must be adhered to.

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

211

INSPECTION REPORT

1	Name & address of the building	Kasturi Devi Public School B-1/60 Vijay Enclave Gali No.2 Palam - Dabri Road New Delhi.			
2	Type of Occupancy	Educational Building "B"			
3	Type of case	New			
4	Details of previous NOC	No.			
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.			
6	Date of inspection	15.10.2013			
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj			
	Name and designation of officers from the building side	Smt. Rekha (Principal)			
8					
9	Year of construction	1994			
		Nil Dated 20.09.2013		Ground +1 But School at GF	
10	Applicant's letter No.				
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Edu. Circular/NBC Requirement	Provided at site	Remarks	MR / NMR
1	Access to building				
	1) Road width	Required	6 Mtr Provided	MR	
	2) Gate width	N/A	2.5Mtrs.	MR	
	3) Width of internal road	N/A	N/A	N/A	
2	Number, width Type & arrangement of exits				
	a. Number of staircases				
	1. Upper floors	1 No.	1 No. Provided	MR	
	2. basements	N/A	N/A	N/A	
	b. Width of staircase				
	1. Upper floors	N/A	1.25 Mtr, Provided	MR	
	2. basements	N/A	N/A	N/A	
	c. Protection of exits				
	1. Fire check door	N/A	N/A	N/A	
	2. Pressurization	N/A	N/A	N/A	
	d. No. of continuous staircase to terrace	N/A	One Provided	MR	
	e. Width of corridor	N/A	N/A	N/A	
	f. Door size	Required	1 Mtr Provided	MR	
3	Compartmentation.				
	1. Fire check door	N/A	N/A	N/A	
	2. Sealing of electrical shafts	N/A	N/A	N/A	
	3. Fire Rating of shaft door	N/A	N/A	N/A	
	4. water curtain	N/A	N/A	N/A	
	5. Fire dampers	N/A	N/A	N/A	
4	Smoke Management system.				
		30 a/c per hour	12	N/A	
	basement	a/c per hour		N/A	N/A

5	Fire Extinguishers			
	total numbers	ISI	2 Nos	MR
	Types		ABC	MR
ISI marking	Provided		MR	
6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	NA
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A


413

	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up for your approval and signature please.



DO. SW.

Sunny
21/11/13

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

Please put up corrected DFA.