

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


Fax:- 011-23412593 E-mail ID: cfohq.dlfire@nic.in Ph – 011-23414333

No F6/DFS/MS/2013/NOZ/1224 Dated 26/11/13

FIRE SAFETY CERTIFICATE

Certified that the **Thapar House at, 124, Janpath, New Delhi** comprised Basement + ground/Mezzanine + 04 upper floors was granted NOC by this department vide letter No.F6/MS/DFS/2010/HR/2506/NOC/67 dated 25/01/2010. The premises was re-inspected by the officer concerned of this department on 24-10-2013 in the presence of Sh. S.K. Gangal vice President & Sh. Vijay Arora (GM) and found that the said Business building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises, is fit for occupancy Business class Group E(3) Sub Division with effect from 26/11/2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on26/11/13..... at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Thapar House at,
124, Janpath, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

2/5

INSPECTION REPORT

- 1. Name & address of the building : Thapar House at 124, Janpath, New Delhi.
- 2. Type of Occupancy : Business Building (B + G + 4 floors)
- 3. Type of Case : Renewal
- 4. Details of previous NOC : F6/MS/DFS/2010/HR/2506/NOC/67 Dt 25/01/2010
- 5 Fire Safety directives Letter No. : NA
- 6 Date of inspection : 24/10/2013
- 7 Name of the Inspecting Officer : M.K.Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Sh. S.K. Gangal Vice President & Sh. Vijay Arora (GM)
- 9 Year of Construction : 2005
- 10. Applicant's letter No. : Nill

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	6 mts	6 mts	MR
	• Gate width	1 mt	1.5 mt	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	02	02	MR
	b.Width of staircases			
	• Upper floors	1200 mm	1400 mm	MR
	• Basements	1000 mm	800	MR
	c..Protection of exits			
	• Fire check door	YES	P	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace			
		02	02	MR

Mansh

	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	YES	P	MR
	• Sealing of electrical shafts	YES	P	MR
	• Fire Rating of shaft door	30 mt	P	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	20	25	MR
	• Types	Co ₂ , ABC,	P	MR
	• IS marking	YES	P	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	02	P	MR
	• Length of hose reel hose	30 Mts	P	MR
	• Nozzle diameter	05 mm	P	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NR	P	MR
	• Location of Main Panel	G. floor	P	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	Each floor	P	MR
8	MOEFA	NR	P	MR
9	Public Address System	NR	P	MR
10	Automatic Sprinkler System			
	• Basements	YES	P	MR
	• Upper Floor	YES	P	MR
	• Sprinkler above false ceiling	NA	NA	NA

2/7

11	Internal Hydrants			
	• Size of riser/down- comer	150 mm	P	MR
	• Number of hydrants per floor	02	P	MR
	• Hose Box	02	P	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level	NA	NA	NA
	• Discharge of main pump	2280	P	MR
	• Head of main pump	75 mt	P	MR
	• Number of main pumps	01	P	MR
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	180 LPM	P	MR
	• Power supply	30 mt	P	MR
	• Auto starting of pump	YES	P	MR
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	1,00,000	1,00,000 lacs	MR
	Draw of connection	NA	NA	NA
	• Fire service inlet	YES	P	MR
	• Access to tank	YES	P	MR
	• Overhead Tank capacity	20,000 lts	20,000 lts	MR
15	Exit Signage	R	P	MR
16	Provision of Lifts			

N/18

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	YES	P	MR
	• Fireman's Grounding Switch	YES	P	MR
	• Lift Signage	YES	P	MR
17	Standby power supply	YES	P	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	YES	P	MR
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	YES	P	MR
	• Batter backup	YES	P	MR
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / for FSC recommended please.



By CFO (NDZ)

[Handwritten signature]

Signature of the Inspecting Officer

[Handwritten signature: M. K. Sharma]
 21/11/13

Name :- M.K. Sharma
 Designation :- A. D.O. (CC)