

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No.F6/DFS/MS/GH/2013/ 1226

Dated: 26/11/13

FIRE SAFETY CERTIFICATE

Certified that the BUKHARA INN, guest house located at 1066-67, First Floor, Main Road, Paiwalan, Jama Masjid, Delhi-06, comprised of first floor (03 guest rooms + reception), 2nd floor (04 guest rooms), 3rd floor (04 guest rooms), 4th floor (03 guest rooms), total 14 guest rooms, owned/occupied by M/S BUKHARA INN, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on dated 06.11.13 & 14.11.13 in the presence of Sh. Syed Ahmed Bukhari and that the building is fit for occupancy class "Residential" Group A Sub Division A-1 Lodging or Rooming Houses with effect from 26/11/13..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Issued on... 26/11/2013 at New Delhi by


(DR.G.C. MISRA)
CHIEF FIRE OFFICER
(011-23414333)

Copy to:-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-110049 w.r.t. letter No.51127-30/Joint C.P./Lic.(H) dated 1.10.13.
2. M/s Bukhara Inn, 1066-67, First Floor, Urdu Bazar, Jama Masjid, Delhi-06.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : BUKHARA INN,at 1066-67,First Floor, Main Road,Paiwalan, Jama Masjid, Delhi-06
2. Building is comprised of : G+4
3. Type of Occupancy : Lodging House
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 06.11.13&14-11-13
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name of the designation of Officer
from the building side : Sh. Syed Ahmed Bukhari
10. Year of Construction : 1987
11. Applicant's letter No : No.51127-30/Joint C.P./Lic.(H) dated 1.10.13

S.No	Minimum Standards on fire prevention and fire safety U/R33	BBL Requirements	Provided at Site	Remarks MR/NMR (P.S.S. Area)
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
Upper Floor Basement	a. Number of Staircases	1 no.	2 nos. upto first floor & 1no. first floor to roof	MR
		1 no.	2 nos. upto first floor & 1no. first floor to roof	MR
		N.A.	N.A.	N.A.
	B. Width of Staircases	80 cms	1 m	MR
	Upper Floor	80cms	1 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	N.A.	N.A.	N.A.
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System. Ventilated			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.



5.	Fire Extinguisher			
	Total numbers	08 nos.	08 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	Not Required	01 Provided	MR
	Length of hose reel hose	30 M	Provided	MR
	Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	35 Mtrs.	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	5000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	D.G. Set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	Required	01Co ₂ &01ABC Fire Extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Vedpal
15/11/13

Signature of the Inspecting Officer

Name Vedpal

Designation ADO

