

NO. F6/DFS/MS/Ind./ 2013/SZ/ 1229

DATED: 26/11/13

FIRE SAFETY CERTIFICATE

Certified that the M/s Sonu Exim Pvt. Ltd., Plot No. 47/10, Block-E, Okhla Industrial Area, Phase-2, New Delhi-110020 comprised of basement, ground, two upper floors owned/occupied by M/s Sonu Exim Pvt. Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 13.11.2013 in the presence of Sh. Ved Parkash (Director), of the Industrial and that the building is fit for occupancy class G "Industrial building" with effect from 26/11/13..... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010, subject to condition as mentioned below.

Issued on 26/11/13..... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service



Copy to,

1. The Executive Engineer (Bldg) HQ, Building Department, SDMC, 8th floor, Civic Centre, Minto Road, New Delhi 110002.
2. Sh. Ved Parkash (Director), M/s Sonu Exim Pvt. Ltd., Plot No. 47/10, Block-E, Okhla Industrial Area, Phase-2, New Delhi-110020.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The basement shall be used strictly as per the provisions of Building Bye laws.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Sonu Exim Pvt. Ltd. , Plot No. 47/10, Block-E, Okhla Industrial Area, Phase-2, New Delhi-110020.		
2	Type of Occupancy	Industrial building "G"		
3	Type of case	New		
4	Details of previous NOC	No		
5	Fire safety directives letter No	F6/DFS/MS/BP/2013/2361 dated 03.10.2013		
6	Date of inspection	13.11.2013		
7	Name of the inspecting Officers	DO Dharampal Bhardwaj & ADO M.K. Chattopadhyay		
8	Name and designation of officers from the building side	Sh. Ved Parkash (Director)		
9	Year of construction	1986		
10	Applicant's letter No.	Nil	16.10.2013	basement, ground, two upper floors
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	BBL-1983/NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	10 Mtr Provided	MR
	2) Gate width	Required	5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Provided	MR
	2. basements	Two	Provided	MR
	b. Width of staircase			
	1. Upper floors	1.25 Mtr	1.25 & 1.16 Mtr Provided	MR
	2. basements	1.25 Mtr	1.2 & 1.25 Mtr Provided	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	Two Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	1 Mtr	N/A
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	12 Exhust Fans Provided	MR
	upper floors	a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers		26 Nos. Provided	MR
	Types		ABC, CO2 & Water Co2	MR
	ISI marking	ISI	Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR

7	Automatic fire detection and alarming system			
	Type of detectors	Required	Smoke Provided	MR
	location of Main Panel	Required	Ground Floor Provided	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Provided	MR
	hooter's location	Required	Staircase Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	150 MM	Provided	MR
	Number of Hydrants per floor	Required	One Provided	MR
	hose Box	Required	One Provided	MR
12	Yard Hydrants.			
	total number of hydrants	Required	4 Nos. Provided	MR
	house box	Required	4 Nos. Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2280 LPM	Provided	MR
	b. Head of main pump	60 Mtr	Provided	MR
	c. Number of main pumps	One	Provided	MR
	d. jockey pump out put	180 LPM	Provided	MR
	e. jockey pump head	60 Mtr	Provided	MR
	f. Standby Pump output	2280 LPM	Provided	MR
	g. Stanby Pump head	60 Mtr	Provided	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	900 LPM	900 LPM Provided	MR
	b. head of the pump	40 Mtr	40 Mtr	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	75,000 ltr	Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	d. Over head tank Capacity	20,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. Pressurization of lift lobby	N/A	N/A	N/A
	c. Communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR

8	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: Co2 Fire Extinguishers Provi			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up for your approval and signature please.



Signature of the inspecting officer

Name Dharampal Bhardwaj

Designation : Divisional Officer



Signature of the inspecting officer

Name M.K. Chattopadhyay

Designation : ADO