

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in

No F6/DFS/MS/School/2013/ND2/1232

Dated: 27/11/13

FIRE SAFETY CERTIFICATE

Certified that the NP Primary School at, R. K. Ashram Marg, New Delhi comprised of ground plus one upper floor was granted NOC by this department vide letter No. F6/DFS/MS/2008/390 dated 13-02-2008. The premises was re-inspected by the officer concerned of this department on 18-09-2013 in the presence of Mrs. Rama Joshi (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class B "Educational Building" with effect from ~~27/11/~~2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to the condition printed overleaf.

Issued on27/11/13..... at New Delhi by.



(Dr. G. C. Misra)
Chief fire officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. NP Primary School at, R. K. Ashram Marg, New Delhi.
- 2.. The Director Education, Old Secretariat, Delhi – 110054.



Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

N/3

INSPECTION REPORT

1. Name & address of the building : NP Primary School at, R. K. Ashram Marg, New Delhi.
 2. Type of Occupancy : Educational GF+FF
 3. Type of Case : RENEWAL
 4. Details of previous NOC : F6/DFS/MS/GH/2008/390 Dted 13-02-2008
 5 Fire Safety directives Letter No. : NA
 6 Date of inspection : 18/09/2013
 7 Name of the Inspecting Officer : M.K. Sharma (Assistant Divisional Officer)
 8 Name and designation of Officer
 from the building side : Mrs. Rama Joshi (Principal)
 9 Year of Construction : 2005
 10. Applicant's letter No. : The director education, old secretariat, New delhi

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	12 mt	12 mt	MR
	• Gate width	5 mt	5 mt	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	P	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

merit

N/4

	e No of continuous staircase to terrace	01	P	MR
	g.Width Of Corridor	1250	1500	MR
	j. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	6	P	MR
	• Types	CO ₂ , ABC, Wco ₂	P	MR
	• IS marking	YES	P	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	04	P	MR
	• Length of hose reel hose	30	P	MR
	• Nozzle diameter	05 mm	P	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NR	P	MR
9	Public Address System	NR	P	MR
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA

N/S

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	NA NA	NA NA	NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	NA NA NA	NA NA NA	NA NA NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> ○ Ground Level • Discharge of main pump • Head of main pump • Number of main pumps • Jockey pump out put • Jockey pump head • Standby Pump out put • Standby Pump Head • auto Staring/Manual stopping • Pump House Access ○ Terrace level • Discharge of pump • Head of the pump • Power supply • Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 LPM 30 mt YES NA	NA NA NA NA NA NA NA NA NA NA P P P NA	NA NA NA NA NA NA NA NA NA NA MR MR MR NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity • Draw of connection • Fire service inlet • Access to tank 	NA NA NA YES	NA NA NA P	NA NA NA MR

Mark

N/6

	• Overhead Tank capacity	2500	2500	MR
15	Exit Signage	YES	P	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	(ABC, Co ₂)	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the Substantial compliance of the minimum standards on fire prevention and Fire Safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / for FSC please.



Dy CPO (NDZ)
 [Handwritten signature]

Signature of the Inspecting Officer

M.K. Sharma
 11/11/13

Name :- M.K. Sharma
 Designation :- A. D.O. (CC)