


No F 6 / DFS / MS / GH / 2013 / N02/1233

Dated 27/11/13

FIRE SAFETY CERTIFICATE

Certified that **The Spirit Restaurant Located at E-34 Inner Circle 1st floor Connaught place New Delhi** comprised of ground plus two upper floors building was granted NOC by this department vide letter No. F6/DFS/MS/2011/EH/436 dated 07-03-2011. The premises was re-inspected by the officer concerned of this department on 28-09-2013 in the presence of Sh. Karan Manager Admin and status of building is as under:- The building is comprised of ground floor plus two upper floors and E 35 is further addition in E- 34 (**E-34 & E-35 Inner Circle 1st floor Connaught Place New Delhi**). The owner's have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D of Sub Division D-4** with effect from 27/11/---2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 27/11/13 at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph - 011-23414333

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi -110049

2. M/s RJP Restaurants & Hotels (P) Ltd.,
E-34 & E-35 Inner Circle 1st floor Connaught Place New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

N/15

INSPECTION REPORT

1. Name & address of the building : SPIRIT – RESTAURANT , M/S RJP Restaurants & Hotels (P) LTD. 1st floor E- 34 & E- 35 Connaught Place, New Delhi-110055
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Renewal & Add. All.
4. Details of previous NOC : F6/DFS/MS/2011/E-71/436 Dted 07-03-11
- 5 Fire Safety directives Letter No. : F6/DFS/MS/2012/4736 Dated 21-12-12
- 6 Date of inspection : 28/09/2013
- 7 Name of the Inspecting Officer : M.K.Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer from the building side : Sh. Karan Manager Adm. (RJP)
- 9 Year of Construction : Existing Bld. in Inner Circle CP.
10. Applicant's letter No. : dated 02/09/13

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	NA	15 mt	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1 mt	1200, 1000 cm.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	YES	P	MR
	• Pressurization	NA	NA	NA

Mishra

N/16

	e.No of continuous staircase to terrace	01	P	MR
	g.Width Of Corridor	NA	NA	NA
	q.Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	YES	P	MR
	• Sealing of electrical shafts	YES	P	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	06	12	MR
	• Types	Co ₂ , ABC, Wco ₂	P	MR
	• ISI marking	YES	P	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	P	MR
	• Length of hose reel hose	36 mt	P	MR
	• Nozzle diameter	05 mm	P	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NR	P	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA

N/18

	• Overhead Tank capacity	5000 mesh	P	MR
15	Exit Signage	R	P	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NR	P	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / for the said building.

M.K. Sharma
11/11/13

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- A. D.O. (CC)

Do (ED)
DCFO (WD2)
submitted please
15-10-13
Kamraj
6/11

