

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2013/ WZ / 1236

Dated: 27/11/13

FIRE SAFETY CERTIFICATE

Certified that the **M. D. Public School** at **Baba Hari Das Colony, Tikri Border, Delhi-110041**, owned / occupied by **M. D. Public School Society** has already been issued Fire Safety Certificate by this department vide letter No. F6/MS/DFS/2006/1874 dated 02/08/2006 for Ground Floor only. The premises was re-inspected by the officer concerned of Fire Service on **29.10.2013** in presence of **Sh. Naveen Dahiya (Teacher)** and found that premises is now comprised of Ground + One Upper Floor have complied with the fire prevention and Fire Safety requirements in accordance with Director of Education **Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011** and that the building / premises is fit for occupancy class **Educational** with effect from **27/11/13**.....for a period of 3 (three) years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 27/11/13 at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250
E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Sh. Raghubir Singh (Owner), M. D. Public School, Baba Hari Das Colony, Tikri Border, Delhi-110041.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

N3
G+1

INSPECTION REPORT

1. Name & address of the building: MD Public School, Baba Hari Das Colony
Tikri Border, Delhi - 110041
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : Letter No
5. Fire Safety directives Letter No. : DOE circular 1/3/2011
6. Date of inspection : 29/x/2013
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer
from the building side : Navin Dahiya
9. Year of Construction : G.F (2006), G+1 (2011)
10. Applicant's letter No. : NIL

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/DOE order 1/3/11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	1	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door			
	• Pressurization		NR	
	d. No of continuous staircase to terrace	one	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1000 Mtr.	Provided	MR

NA

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NR	
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	open sky	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	4 ABC/CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		NR	
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detector • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		NR	
8.	MOEFA		NR	
9.	Public Address System		NR	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 		NR	

11.	Internal Hydrants			
	<ul style="list-style-type: none">• Size of riser/down- comer			
	<ul style="list-style-type: none">• Number of hydrants per floor		NR	
	<ul style="list-style-type: none">• Hose Box			
12.	Yard Hydrants			
	<ul style="list-style-type: none">• Total number of hydrants		NR	
	<ul style="list-style-type: none">• Hose Box			
13.	Pumping Arrangements			
	<ul style="list-style-type: none">• Ground Level			
	<ul style="list-style-type: none">• Discharge of main pump			
	<ul style="list-style-type: none">➤ Head of main pump			
	<ul style="list-style-type: none">➤ Number of main pumps			
	<ul style="list-style-type: none">➤ Jockey pump out put			
	<ul style="list-style-type: none">➤ Jockey pump head			
	<ul style="list-style-type: none">➤ Standby Pump out put			
	<ul style="list-style-type: none">➤ Standby Pump Head		NR	
	<ul style="list-style-type: none">➤ Auto Staring/Manual stopping			
	<ul style="list-style-type: none">➤ Pump House Access			
	<ul style="list-style-type: none">• Terrace level			
	<ul style="list-style-type: none">➤ Discharge of pump			
	<ul style="list-style-type: none">➤ Head of the pump			
	<ul style="list-style-type: none">➤ Power supply			
	<ul style="list-style-type: none">➤ Auto starting of pump			
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none">• Under ground tank capacity			
	<ul style="list-style-type: none">➤ Draw of connection			
	<ul style="list-style-type: none">➤ Fire service inlet		NR	
	<ul style="list-style-type: none">➤ Access to tank			
	<ul style="list-style-type: none">• Overhead Tank capacity			

15	Exit Signage			
16.	Provision of Lifts		NR	
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car		NR	
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply		NR	
18.	Refuge Area			
	➤ Total area			
	➤ Location		NR	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel		NA	
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Not any special Risk seen		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~

Note: Earlier it was ground Floor only. Now Management has added one more floor. There are 5 Rooms on Ground Floor & 6 Rooms on 1st Floor.

[Signature]
29/11/13

Contd. on N7

M.D. Public^{N^o 7} School, Baba Haridas
Colony, Tikeri Border, Delhi-44


29/11/13

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

(A.K. JAISWAL)

Name

Designation

ADD (JWP)

Designation