


NO.F6/DFS/MS/EH/2013/ SZ/ 1280

DATED: 05/12/13

FIRE SAFETY CERTIFICATE

Certified that the M/s Classic Diplomet Restaurant , A-4, Khasra No. 340-342, Mahipal Pur New Delhi-110037 running at the ground floor of a building comprised of basement, ground plus four upper floors (4th floor sealed) owned/occupied New Age Hotels Resort Ltd by M/s Classis Diplomet Restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 08.11.2013 in the presence of Sh. Manoj Bajpai (Manager), of the restaurant and that the building is fit for occupancy class D "Assembly building (Restaurant)" with effect from...05/12/13 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010, as mentioned below.

Issued on05/12/13.... at New Delhi by


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

etc

Copy To:-

1. The DHO (Najafgarh Zone), Office of Deputy Health Officer, M.C.D. Public Health Department, Najafgarh Zone, Najafgarh, New Delhi-110043.
2. The Authorized Signature , M/s Classic Diplomet Restaurant , A-4, Khasra No. 340-342, Mahipal Pur New Delhi-110037

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Classic Diplomet Restaurant , A-4, Khasra No. 340-342, Mahipal Pur New Delhi-110037.		
2	Type of Occupancy	Assembly "D" Resturant		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	No		
6	Date of inspection	08.11.2013		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO S.S. Kaushik		
8	Name and designation of officers from the building side	Mr. Manoj Bajpai (Manager)		
9	Year of construction		Restaurant running at ground floor	
10	Applicant's letter No.	DHO/NGZ/2013/1698 dated 18.10.2013	Basement Ground plus four upper floors	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	---------------------

1	Access to building			
----------	---------------------------	--	--	--

	1) Road width	Required	20 Mtr Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
----------	--	--	--	--

	a. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	2.00 & 1.00 Mtr Provided	MR

3	Compartmentation.			
----------	--------------------------	--	--	--

	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
----------	---------------------------------	--	--	--

	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Exhust Fans Provided	MR

5	Fire Extinguishers			
----------	---------------------------	--	--	--

	total numbers		5 Nos	MR
	Types		ABC, Co2,	MR
	ISI marking	ISI	Yes	MR

6	First-Aid Hose Reels.			
----------	------------------------------	--	--	--

	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR

7	Automatic fire detection and alarming system			
	Type of detectors	N/A	Smoke	MR
	location of Main Panel	N/A	Ground floor	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	Batter Backup	MR
	hooter's location	N/A	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	Provided <i>in Restaurant</i>	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/ Terrace level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM Provided	MR
	b. head of the pump	Required	35 Mtr	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000 Ltr	10,000 ltr Provided	NMR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	total area	Not Required		
	location			

19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:			N/A.


The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. The grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)



Signature of the inspecting officer

Name: S.S. Kaushik

Designation : ADO/SJ

