

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001


NO. F6/DFS/MS/School/2013/ 52 / 1282

Dated: 05/12/13

FIRE SAFETY CERTIFICATE

Certified that Nutan Public School located at RZ-A-10, Street No-9, Main Nasirpur Road, Durga Park New Delhi 110045, comprised of ground plus one upper floor owned/occupied by Nutan Public School have complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011 issued by Directorate of Education, Govt of NCT of Delhi and verified by officer concerned of this department on 26-11-2013 in presence of Mrs Lat Gupta Principal and therefore the fire safety norms as required under rule 33 of Delhi Fire Service Rules,2010 are deemed complied with and that the premises / building is fit for occupancy of class B, "Educational Building" for ground plus one upper with effect from 05/12/13 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to conditions as mentioned below.

Issued on 05/12/13 at New Delhi by.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Tel: - 011-23414333

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. The Principal, Nutan Public School, RZ-A-10, Street No-9, Main Nasirpur Road, Durga Park New Delhi 110045

Conditions for the validity of Fire Safety Certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time.
- b. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- c. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- d. The trained fire fighting staff shall be available round the clock.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	Nutan Public School RZ -A -10, Street No. 9, Main Nasirpur Road, Durga Park, New Delhi-110045		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New		
4	Details of previous NOC	No		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	20.11.2013		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Lata Gupta (Principal)		
9	Year of construction			
10	Applicant's letter No.	1005 Dated.26.11.2013	(ground plus one upper floor)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	-------------------------------------------------------------	-----------------	------------------	------------------

1	Access to building			
	1) Road width	6 Mtrs.	9 Mtr Provided	MR
	2) Gate width	Required	3 Mtrs. Provided	MR
	3) Width of internal road	6 Mtrs.	6Mtrs.	M/R

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Required	1 No. Provided	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	One Provided	MR
	e. Width of corridor	N/A	1.25 Mtr Provided	MR
	f. Door size	Required	1 Mtr Provided	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
	total numbers	4 Nos.	6 Nos	MR
	Types	CO2 OR ABC	ABC	MR
	ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

MA

1-2 *Seq*

N/3

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for your approval and signature please.

S.P. Bhardwaj
27/11/13

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)