

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

Fax:23412593,E-mail:cfohq.dfire@nic.in

NO. F6/DFS/MS/school/ND2/1287

DATED: 05/12/2013

FIRE SAFETY CERTIFICATE

Certified that the Shanti Niketan Public School at B-Block, Ankur Enclave, Karawal Nagar, Delhi -110094. owned/occupied by Shanti Niketan Public School, comprising of ground plus two upper floors was granted NOC for ground plus first floor only vide letter no. No.F.6/MS/DFS/2006/2611 dated 15/09/2006.The school building was inspected by the officer concerned of this department on 18/11/2013 in the presence of Mr. Atul Bansal, Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy class B "Educational Building" with effect from .05.12.2013 for a period of three years, subject to conditions printed overleaf.

Issued on .....05/12/2013... at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph. 23414333

gc  
Atul  
02.12.13

To,

The Manager,  
Shanti Niketan Public School,  
B-Block, Ankur Enclave,  
Karawal Nagar, Delhi -110094.

Copy to:-

The Dy. Director of Education,  
North-East, B-Block,  
Yamuna Vihar, Delhi-53.

**- Conditions -**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : Shanti Niketan Public School, B-Block,  
Ankur Enclave, Karawal Nagar, Delhi -110094.
2. Building is comprised of : Ground plus two upper floor only
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : F-6/MS/DFS/2006/2611 Dated-15/09/2006  
(for Ground & first Floor only)
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 18/11/2013
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer:  
from the building side : Mr. Atul Bansal (Manager)
10. Year of Construction : 2005-Ground plus 1<sup>st</sup> floor & 2011-II<sup>nd</sup> floor
11. Applicant's letter No : Letter No. – 1030/SNPS, Dated- 06/11/2013

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06mtr.	06mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01Nos.	02Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr. or less	1.30&0.84mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 Nos.	02 Nos.	MR
	e. Width of Corridor	1.50mtr.	1.75mtr.	MR
	f. Door Size	01mtr.	01mtr.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

Shanti Niketan Public School, B-Block, Ankur Enclave, Karawal Nagar, Delhi -110094.

**INSPECTION REPORT**

1. Name & address of the building : Shanti Niketan Public School, B-Block,  
Ankur Enclave, Karawal Nagar, Delhi -110094.
2. Building is comprised of : Ground plus two upper floor only
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : F-6/MS/DFS/2006/2611 Dated-15/09/2006  
(for Ground & first Floor only)
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 18/11/2013
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer:  
from the building side : Mr. Atul Bansal (Manager)
10. Year of Construction : 2005-Ground plus 1<sup>st</sup> floor & 2011-II<sup>nd</sup> floor
11. Applicant's letter No : Letter No. – 1030/SNPS, Dated- 06/11/2013

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06mtr.	06mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01Nos.	02Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr. or less	1.30&0.84mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 Nos.	02 Nos.	MR
	e. Width of Corridor	1.50mtr.	1.75mtr.	MR
	f. Door Size	01mtr.	01mtr.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

Shanti Niketan Public School, B-Block, Ankur Enclave, Karawal Nagar, Delhi -110094.


4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	07 nos.	08 nos.	MR
	• types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30mtr.	30mtr.	MR
	• Nozzle diameter	05mm	05mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	Not Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 Lpm.	450 Lpm.	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Electricity	MR
	➤ Auto Starting of pump	Required	Provided	MR

I R W - 5

14	Cap tive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.



*[Handwritten Signature]*  
23/11/13

Signature of the Inspecting Officer

*[Handwritten Signature]*  
DQ(ED)