

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in

No F 6 / DFS / MS / GH / 2013 / ND2/1302

Dated 11/12/13

FIRE SAFETY CERTIFICATE

Certified that the **M/s Chew Restaurant at, M- 16 , 1st floor, Connaught Place, New Delhi – 110001** occupied by Shree Bhagwati Consultants & Farms Development Pvt. Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of the fire service on 26/11/2013 in the presence of Sh. Vijay Kumar Arora (Partner) and the said building / premises is fit for occupancy **Class Group D Assembly Building** with effect from ~~11/12/13~~ 2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11/12/13..... at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. M/s Chew Restaurant at, M- 16 , 1st floor, Connaught Place, New Delhi – 110001
2. Medical officer of Health, Health Department, Palika Kendra, New Delhi – 110001
No. D/126/MOH/CSI (Lic)/SI-I dated 25/11/2013

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

2/11

INSPECTION REPORT

- 1. Name & address of the building : M/s Chew Restaurant M- 16, 1st Floor, Connaught Place, New Delhi.
- 2. Type of Occupancy : Restaurant at F. floor
- 3. Type of Case : New
- 4. Details of previous NOC : NA
- 5. Fire Safety directives Letter No. : NA
- 6. Date of inspection : 26/11/2013
- 7. Name of the Inspecting Officer : M.K.Sharma (Assistant Divisional Officer)
- 8. Name and designation of Officer
from the building side : Sh. Vijay Kumar Arora (Partner)
- 9. Year of Construction : Existing Heritage Bldg. (C.C.)
- 10. Applicant's letter No. : No.D126/MOH/CSI(Lic)/SI-I dated 25/11/2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	NA	20 Mt	MR
	• Gate width	2 mt & 1.5 mt	2 mt & 1.5 mt	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02	02	MR
	• Upper floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mt & 1 mt	1.5 mt & 1 mt	MR
	• Basements	NA	NA	NA
	c..Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

Mesha

n/2

	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size / Exit	1.5 mt	2 mt & 1.5 mt	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	06	10	MR
	• Types	CO ₂ , ABC, Wco ₂	CO ₂ , ABC, Wco ₂	MR
	• IS marking	YES	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA

2/3

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	<p>YES</p> <p>NA</p>	<p>Provided</p> <p>NA</p>	<p>MR</p> <p>NA</p>
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>150 mm</p> <p>01</p> <p>01</p>	<p>150 mm</p> <p>01</p> <p>01</p>	<p>MR</p> <p>MR</p> <p>MR</p>
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>450 LPM</p> <p>30 Mt</p> <p>YES</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>450 LPM</p> <p>30 Mt</p> <p>Provided</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>MR</p> <p>MR</p> <p>MR</p> <p>NA</p>
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	<p>NA</p> <p>NA</p> <p>NA</p> <p>YES</p> <p>5000 ltrs</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>Provided</p> <p>10,000 ltrs</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>MR</p> <p>MR</p>

Messh

2/4

15	Exit Signage	YES	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	YES	Provided	MR
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	YES	Provided	MR
17	Standby power supply	NR	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / for FSC is recommended for first floor restaurant please.



Dy CRO (ND2)

Signature of the Inspecting Officer

M.K. Sharma
9/11/13

Name :- M.K. Sharma
Designation :- A. D.O. (CC)