

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333

NO.F6/ DFS/ MS/School/2013/ 52/1293

Dated: 10/12/13

FIRE SAFETY CERTIFICATE


Certified that, Mother Mary Public School, Located at Phase-V, Aya Nagar Colony, New Delhi-110047, comprised of Ground Floor, having total 20 rooms,(16class room,02office,01Store,01staff room) owned/occupied by Mother Mary Public School Management was granted NOC by this department vide letter no. F6/DFS/MS/20102318 Dated-06/08/10. The premises was re-inspected by the officer concerned of this department on 27/11/2013 in presence of Mr.Omkar Tyagi (Manager) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Directorate of Education dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on 10/12/13 at New Delhi by.


(Dr. G.C. Misra)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

The Manager,
Mother Mary Public School,
Phase-V, Aya Nagar Colony New Delhi-110047

92 
9/12/13

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N-3

INSPECTION REPORT

1. Name & address of the building :Mother Mary Public School, Phase -V, Aya Nagar Colony,
New Delhi-110047
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/20102318 Dated-06/08/10
5. Fire Safety directives letter No : F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011.
6. Date of inspection : 27-11-2013
7. Name of the Inspecting Officers : ADO D.B.Mukherjee
8. Name and designation of officers
from the building side : Mr.Omkar Singh Tyagi,(Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : Nil dated: 18/09/2013, (Ground Floor Only)

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--|---|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | Required | Provided | MR |
| | • Gate width | Required | Provided | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| a. Number of staircases | | | | |
| • Upper Floors | N/A | | N/A | N/A |
| • Basements | N/A | | N/A | N/A |
| b. Width of staircases | | | | |
| • Upper Floors | N/A | | N/A | N/A |
| • Basements | N/A | | N/A | N/A |
| c. Protection of exits | | | | |
| • Fire check door | N/A | | N/A | N/A |
| • Pressurization | N/A | | N/A | N/A |
| e. No. of continuous staircases to terrace | N/A | | N/A | N/A |
| g. Width of Corridor | N/A | | N/A | N/A |
| h. Door Size | N/A | | N/A | N/A |

✓

N/4

| | | | | |
|----|---|---------------------|----------|-----|
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> • Fire check door | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Sealing of electrical shafts | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Fire Rating of shaft door | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Water Curtain | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Fire Dampers | N/A | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basements | 30 a/c per hour | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper floors | 12 a/c per hour | N/A | N/A |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers | Required | 07 Nos. | MR |
| | <ul style="list-style-type: none"> • Types | ABC,CO ₂ | Provided | MR |
| | <ul style="list-style-type: none"> • IS marking | Required | Provided | MR |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor | 01 | N/A | N/A |
| | <ul style="list-style-type: none"> • Length of hose reel hose | 30 m | N/A | N/A |
| | <ul style="list-style-type: none"> • Nozzle diameter | 5 mm | N/A | N/A |
| 7 | Automatic fire detection and alarming system. | Not required | | |
| | <ul style="list-style-type: none"> • Type of detectors | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Location of Main Panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Location of Repeater Panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Alternate source of power | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Hooters' Location | N/A | N/A | N/A |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> • Basement | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper Floor | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Number of hydrants per floor | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Hose Box | N/A | N/A | N/A |

✓

| | | | | |
|----|--|-----------------------|----------|-----|
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/ Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the pump | N/A | N/A | N/A |
| | ➤ Power Supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | N/A | N/A | N/A |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | Not Applicable | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |



N-6

| | | | | |
|----|--|-----|-----|-----|
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | | | |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to renew fire safety certificate under rule 35 of the Delhi Fire Service rules 2010. *Accordingly D.F.M. is put up for sign pt.*

DO (52)

[Signature]
21/11/13

Signature of the Inspecting Officer

[Signature]
27/11/2013

Name (D.B. Mukherjee)

Designation :- Assistant Divisional Officer