

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/Club/2013/W2/1297 Dated: 10/12/2013

FIRE SAFETY CERTIFICATE

Certified that Roshanara Club Ltd. located at Roshanara Garden, Delhi-110084 was granted NOC by this department vide letter no F.6/DFS/MS/2007/306 dated 02/02/2007. The premises was re-inspected by the officers concerned of this department on 18/11/2013 in the presence of Col. K. B. Sharma and found that the building/premise have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly building sub div D-5 occupancy with effect from 10/12/2013 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. The basement shall only be used as per building bye laws 1983.

WWW.dfs.Delhigovt.nic.in

Issued on 10/12/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Secretary, Roshanara Club Ltd, Roshanara Garden, Delhi-110084



INSPECTION REPORT


1. Name & address of the building: Roshanara Club Ltd, Roshanara Garden, Delhi-110084
2. Type of Occupancy : **Assembly** (G + 1)
3. Type of Case : Renewal
4. Details of previous NOC : Letter no F.6/DFS/MS/2007/306 dated 02/02/2007
5. Fire Safety directives letter No : F.6/DFS/MS/BP/93/1516 dated 09/09/1993
6. Date of inspection : 18/11/2013
7. Name of the Inspecting Officers : DCFO (WZ) Vipin Kental & DO (NW)
8. Name and designation of officers
from the building side : Col. K.B. Sharma
9. Year of Construction : 1993
10. Applicant's letter No. : 23/05/2013

	Minimum Standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	N/A	06 M	N/A
	• Gate width	5 mtr	P	M/R
	• Width of internal road	5 mtr	P	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	03
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	R	P	M.R
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	R	P	M.R
	g. Width of Corridor	1.2 mtr	P	M.R
	h. Door Size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door	R	P	M.R
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	P	M/R
	• Upper floors	12 a/c per hour	Natural/Ventilation	M/R

14	Captive Water Storage for fire fighting.				
	• Underground tank capacity	1,00,000 ltr	P	M/R	
	➤ Draw-off connection	R	P	M.R	
	➤ Fire service inlet	R	P	M.R	
	➤ Access to tank	R	P	M.R	
	• Overhead Tank capacity	5,000 Ltr	P	M.R	
15	Exit Signage.		N/A	P	N/A
16	Provision of Lifts.				
	• Pressurization of Lift Shaft	N/A	N/A	N/A	
	• Pressurization of Lift lobby	N/A	N/A	N/A	
	• Communication In lift Car	N/A	N/A	N/A	
	• Fireman's Grounding Switch	N/A	N/A	N/A	
	• Lift Signage	N/A	N/A	N/A	
17	Standby power supply		N/A	P	N/A
18	Refuge Area.				
	➤ Total Area	N/A	N/A	N/A	
	➤ Location	N/A	N/A	N/A	
19	Fire Control Room				
	• Detector System Panel	N/A	P in lobby	N/A	
	• Flow Switch Panel	N/A	N/A	N/A	
	• PA System Panel	N/A	N/A	N/A	
	• Batter backup	N/A	N/A	N/A	
	• Building Floor Plans	N/A	N/A	N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:		--	No Special risk seen at time of inspection	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer
 Name. *rupin icental*

Designation *DePo.*

Signature of the Inspecting Officer
 Name
18/11/13
DO (nw)

Designation