

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2013/ 52/1317

DATED: 18/12/13

**FIRE SAFETY CERTIFICATE**

Certified that Sri Krishna Vidyapeeth V & P.O.Kanganheri New Delhi -110 071, comprised of ground floor plus one upper floor owned/occupied by Sri Krishna Vidyapeeth was granted NOC by this department vide letter No.F6/DFS/MS/09/2994 Dated 09.10.2009 have complied with the fire prevention and fire safety requirements in accordance circular No.F.16/Estate//CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of this department on 06.12.2013 in the presence of Mrs. Priyanka Headmistress of the school and the fire safety norms as required under rule 33 of Delhi Fire Service Rules, 2010 are deemed complied with and that the premises / building is fit for occupancy of class B, 'Educational Building' for ground plus one upper floor with effect from 18/12/13 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, and subject to conditions as mentioned below.

Issued on ....18/12/13..... at New Delhi by

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph. 011 - 23414333

Copy to:

1. The Director (Education), G.N.C.T. of Delhi, Old Secretariat, New Delhi.
2. The Headmistress, Sri Krishna Vidyapeeth V&P.O.Kanganheri New Delhi 110 071

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



## INSPECTION REPORT

1	Name & address of the building	Sri Krishna Vidyapeeth V& P.O Kanganaheri, New Delhi 110071.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal	
4	Details of previous NOC	F/6/DFS/MS/09/2994 Dated 09/10/09	
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.	
6	Date of inspection	6.12.2013	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Mrs. Priyanka (Headmistress)	
9	Year of construction	2007	
10	Applicant's letter No.	1005 Dated.30.11.2013	( ground plus one upper floor)

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	------------------

1	<b>Access to building</b>			
	1) Road width	6 Mtrs.	6Mtr Provided	MR
	2) Gate width	required	2.5 Mtrs. Provided	MR
	3) Width of internal road	N/A	N/A.	N/A

2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Required	2 Nos. Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	1.4Mtrs & 1 Mtr. Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	One Provided	MR
	<b>e. Width of corridor</b>	N/A	2 Mtrs. Provided	MR
	<b>f. Door size</b>	Required	1 Mtr Provided	MR

3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

5	<b>Fire Extinguishers</b>			
	total numbers		6 Nos	MR
	Types		ABC	MR



6	First-Aid hose reels.	N/A	1No. <i>provided</i>	N/A
	total numbers on each floor	N/A	30 Mtrs. <i>provided</i>	N/A
	Length of Hose reel hose	N/A	5mm <i>provided</i>	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	M/R
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	220 Lpm. Provided	N/A
	b. head of the pump	N/A	40 Mtrs.	N/A
	c. Power supply	N/A	N/A	N/A
d. Auto starting of pump	N/A	N/A	N/A	
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	2500 Lts.	N/A
15	Exit Signage.	N/A	N/A	N/A
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

P-2 Sri Krishna vidhyapeeth  
Sri

N/4

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010. Accordingly DFA is put up for your approval and signature please.

  
Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

6/11/13