

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfhq.dlfire@nic.in

No F 6 / DFS / MS / GH / 2013 / NO2 / 1321

Dated 18/12/13

FIRE SAFETY CERTIFICATE

Certified that the **M/s TC & 100% Rock Restaurant at, M-66, 1st floor, Connaught Circus, New Delhi – 110001** occupied by A Unit of ADAAB Hotels Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of the fire service on 10/12/2013 in the presence of Mr. Ashok Juyal (Manager) and the said building / premises is fit for occupancy **Class Group D Assembly Building** with effect from 18/12/-----2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/12/13..... at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. M/s TC & 100% Rock Restaurant at, M-66, 1st floor, Connaught Circus, New Delhi – 110001
2. Medical officer of Health, Health Department, Palika Kendra, New Delhi – 110001
No. D128/MOH/CSI (Lic)/SI-I dated 25/11/2013

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : M/s TC & 100% Rock Restaurant at, M-66, 1st Floor, Connaught Circus, New Delhi
2. Type of Occupancy : ~~Residential~~ at F. floor Restaurant
3. Type of Case : Fresh
4. Details of previous NOC : NA
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 10/12/2013
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Mr. Ashok Juyal (Manager)
- 9 Year of Construction : Existing Heritage Bldg. (C.C.)
10. Applicant's letter No. : No.D128/MOH/CSI(Lic)/SI-I dated 25/11/2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	NA	12 mt	MR
	• Gate width	1 mt & 1.5 mt	1 mt & 1.5 mt	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	03	03	MR
	• Upper floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors * 3 rd staircase of 1 mt from Restaurant to terrace.	1 mt & 1.25 mt	1 mt & 1.25 mt	MR
	• Basements	NA	NA	NA
	c..Protection of exits			

Mesh

	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	02	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	02 mt	02 mt	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	06	10	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	YES	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			

	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	Upper Floor	YES	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> auto Staring/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 	NA	NA	NA
	<ul style="list-style-type: none"> Discharge of pump 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> Head of the pump 	30 mt	30 mt	MR
	<ul style="list-style-type: none"> Power supply 	YES	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump 	NA	NA	NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> Draw of connection 	NA	NA	NA
	<ul style="list-style-type: none"> Fire service inlet 	NA	NA	NA

Mash

	<ul style="list-style-type: none"> • Access to tank • Overhead Tank capacity 	<p>YES 5,000 ltrs</p>	<p>Provided 6,000 ltrs</p>	<p>MR MR</p>
15	Exit Signage	YES	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	<p>NA NA NA NA NA</p>	<p>NA NA NA NA NA</p>	<p>NA NA NA NA NA</p>
17	Standby power supply	NR	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	<p>NA NA</p>	<p>NA NA</p>	<p>NA NA</p>
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	<p>NA NA NA NA NA</p>	<p>NA NA NA NA NA</p>	<p>NA NA NA NA NA</p>
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / 3rd staircase of 1 mt. width is from 1st floor restaurant to terrace, FSC is recommended please.



By CFO (ND2)

[Handwritten signature]

Signature of the Inspecting Officer

M.K. Sharma
17/12/13
Name :- M.K. Sharma
Designation :- A. D.O. (CC)