


No F6/DFS/MS/school/2013/M02/1325 Dated: 20/12/13

FIRE SAFETY CERTIFICATE

Certified that the **NP Middle Girls School at, Gole Market, New Delhi** comprised of ground plus one upper floor was granted NOC by this department vide letter No.F6/DFS/MS/2008/652 dated 04-03-2008. The premises was re-inspected by the officer concerned of this department on 19-09-2013 in the presence of Smt. Santosh Rawat (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class B "Educational Building" with effect from ~~20/12~~ 2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to the condition printed overleaf.

Issued on 20/12/13 at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. NP Middle Girls School at, Gole Market, New Delhi
2. The Director Education, Old Secretariat, Delhi – 110054.

g/c
m

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

2/13

INSPECTION REPORT

1. Name & address of the building : NP Middle Girls School, Gole Market, New Delhi.
 2. Type of Occupancy : Educational (G + 1 Floor)
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/GH/2008/652 dated 04/03/2008
 5. Fire Safety directives Letter No. : NA
 6 Date of inspection : 19/19/2013
 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
 8 Name and designation of Officer
 from the building side : Smt. Santosh Rawat (Principal)
 9 Year of Construction : 2005
 10. Applicant's letter No. : The director education, old secretariat, New Delhi

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	9 mt 4 mt NA	17 mt 4 mt NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	02 NA	02 NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors * The 2nd staircase 1.06 mt originate from 2nd floor to terrace. Basements 	1.5 mt NA	1.1 mt & .84 mt NA	MR NA
	c..Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA

M.K.S

2/4

	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	02	02	MR
	e. Width Of Corridor	1.5 mt	1.5 mt	MR
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	06	10	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	P	MR
	<ul style="list-style-type: none"> • IS marking 	YES	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	02	P	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 mt	P	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 mm	P	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA

2/5

	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> ○ Ground Level • Discharge of main pump • Head of main pump • Number of main pumps • Jockey pump out put • Jockey pump head • Standby Pump out put • Standby Pump Head • auto Staring/Manual stopping • Pump House Access ○ Terrace level • Discharge of pump • Head of the pump • Power supply • Auto starting of pump 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	450 LPM	NA
		30 mt	30mt	NA
		YES	Provided	NA
14	Captive water Storage for fire fighting	NA	NA	NA
	<ul style="list-style-type: none"> • Under ground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> • Draw of connection 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> • Access to tank 	YES	P	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	2500 ltrs	2500 ltrs	MR

Mur

a/b

15	Exit Signage	YES	Provided	MR
16	Provision of Lifts	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NR	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC,Co2	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2008/652 dated 04/03/2008 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Dy CPO (ND2)

[Handwritten signature]

Signature of the Inspecting Officer

[Handwritten signature]

Name :- M.K. Sharma

Designation :- A. D.O. (CC)

