

OFFICE OF THE CHIEF ENGINEER (W) PROJECTS
DELHI JAL BOARD: DELHI SARKAR
VARUNALAYA: PHASE-I: KAROL BAGH: NEW DELHI

No.DJB/F-1(5)/CE(W)Pr./2013/ 74

Dated: 24.1.2013

Instructional Order

A Committee was constituted for selection of material for various dia pipelines to be used in water supply system in Delhi Jal Board under the Chairmanship of Member(WS). A circular was issued by SE(P)W vide letter no.DJB/SE(P)W/F.1(T)/2004/19-56 dated 13.01.2004. The orders issued were reviewed by the technical committee in view of the availability and use of cast iron pipes in the Department and after deliberating on merits and demerits of each pipe material and their suitability for laying under different site & soil conditions, following decisions were taken:

- (i) For proposals involving pipe sizes 100 mm dia to 500 mm dia only DI pipe option is to be considered.
- (ii) For proposals involving sizes above 500 mm dia to 1000 mm dia either of the two DI/MS option can be considered as per requirement at site.
- (iii) For proposals involving above 1000mm dia pipes, only MS pipes (lined and coated) options are to be considered.
- (iv) In case site conditions warrant deviation from the above guidelines listed at I,II & III, approval of concerned Chief Engineer will be mandatory.
(This issues with the approval of competent authority)

EXECUTIVE ENGINEER (EDP)

305
DATE 12/2/13

ALL Chief Engineers

Ed (EDP)

2/4/2

CE(W)Projects

Copy to:

1. CEO DJB for kind information please.
2. Member(Admn.)/Member(Finance)/Member(WS)/Member(Dr.) for kind information please.

M/WS/382
24/1/13
D. No. 286 DL 04/04/13

P. Upload the circular on DJB website too.

CE(Proj) W

3/1/13

CE(W)Projects

Sanyal