

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Fax: 23412593, E-mail: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in), Tel:- 011-23414333


No.F6/MS/DFS/GH/2013/ 52/1361

Dated: 30/12/13

**FIRE SAFETY CERTIFICATE**

Certified that the **TE New Delhi Guest House** Located at **A-3, Pamposh Enclave, Greater Kailash-1, New Delhi-110048** comprised of **Basement, Stilt, Ground Floor + 03 Upper floors**. Basement Floor – Office and vacant, Stilt Floor – Parking, Ground Floor – Reception, waiting lounge, kitchen and Restaurant, First Floor, Second Floor & Third Floor having 08 Guest Rooms at each floors (Total – 24 Guest Rooms), was granted FSC by this department vide letter No.**F6/DFS/MS/GH/2010/3186** dated **15/11/2010**. The premises was re-inspected by the officer concerned of this department on **17/12/2013** in the presence of Mr. Ashok Pandey and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Residential (Guest House)** with effect from 30/12/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 30/12/13 at New Delhi by.



**(Dr. G.C. Misra)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE**

Copy to:-

- (1) Joint. Commissioner of Police Licencing  
1<sup>st</sup> Floor, PS Defence Colony, New Delhi
- (2) Mr. Arjun Thapar  
TE NEW DELHI, A-3 Pamposh Enclave,  
Greater Kailash-1, New Delhi-110048

9/c  
30/12/2013  
ADG(BLP)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building:- **TE New Delhi, A-3, Pamposh Enclave, Greater Kailash-1, New Delhi - 110048**
2. Type of occupancy:- Residential (Guest House)
3. Type of case: - Renewal.
4. Details of previous NOC:-No. F6/DFS/MS/GH/2010/3186 dated 15/11/2010.
5. Fire safety directives No.- No
6. Date of inspection:-17/12/2013
7. Name of the inspecting officer:- D.B.Mukherjee A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr.Ashok Pandey
9. Year of construction:- Nil
- 10.Applicant's letter No:- 48075/Joint.C.P./Lic."(H) New Delhi Dated 17/09/2013, Building is comprised of Basement, Stilt, Ground + 03 Upper Floors

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
<b>1. Access to Building</b>				
	1) Road width	Required	Provided	MR
	2) Gate width	N/A	Approachable	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2. Number, Width Type &amp; Arrangement of Exits</b>				
A. Number of staircases				
	1. Upper floors	Required	Provided 02 Nos.	MR
	2. Basements	Required	Provided 02 exits	MR
B. Width of staircase				
	1. Upper floors	Required	1.28 m & 0.78m	MR
	2. Basements	Required	1.28 m & 0.70m	MR
C. Protection of exits				
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
<b>3. Compartmentation</b>				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4. Smoke Management System</b>				
	1) Basements	30 a/c per hour	Exhaust fan	N/A
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
<b>5. Fire Extinguishers</b>				
	1) Total numbers	ISI Marked	10Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
<b>6. First-Aid Hose Reel</b>				
	1) Total number of each floor	Required	Provided	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR

*2*

<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	DG Set	MR
	5) Hooter's Location	Required	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100 mm.	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	Required	Provided	MR
	2) Hose box	Required	Provided	MR
<b>13.</b>	<b>Pumping Arrangement</b>			
	<b>1) Ground level</b>	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	<b>Terrace level</b>			
	a) Discharge of pump	Required	180 LPM & 900LPM	MR
	b) Head of pump	Required	30m & 44.5 m	MR
	c) Power supply	Required	Electric Supply & also by D.G. Set	MR
	d) Auto starting of pump	Required	Yes	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	Required	5000 Ltrs	MR
<b>15.</b>	<b>Exit Signage.</b>	Yes	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Yes	Provided DG Set	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A


19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2010/3186 dated 15/11/2010 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature If approved.

Submitted please.

Signature of the inspecting officer

  
23/12/2013

Name: - D.B.Mukherjee.

Designation:- Assistant Divisional Officer (BCP)