

C-13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2012/W2/1352 Dated: 27/12/2013

FIRE SAFETY CERTIFICATE

Certified that the Surya Public School, C-1/134 A, Krishan Vihar, Delhi-110086 comprised of Ground + First floor only owned/occupied by Surya Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2010/1722 dated 11/06/2010. The premises was re-inspected by the officer from this department on dated 06/12/2013 in the presence of Dr. K. K. Vashist and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 27/12/2013 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 27/12/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Surya Public School, C-1/134 A, Krishan Vihar, Delhi-110086
2. The Director of Education, Old Secretariat, Delhi



N-5

GF + F.F.

INSPECTION REPORT

1. Name & address of the building: SURYA PUBLIC SCHOOL, C-1/134A,
2. Type of Occupancy: KRISHNA VIHAR, DELHI-86. Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: No F-6/DPS/MS/2010/1722 dt 11-6-10
5. Fire Safety directives letter No: Circular of the Director of Education
6. Date of inspection: 06-12-13
7. Name of the Inspecting Officers: N.P. SHARMA, A.D.O.
8. Name and designation of officers
from the building side: Sen. Dn. K.K. VASHIST.
9. Year of Construction: 1997
10. Applicant's letter No.: 16-9-13

PA - 6.35 Syds. CA - 2.50 Syds. Nols S-220 No/T-5. No/CR-9

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M.R. ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	M.R. ✓
	• Upper Floors	01	02	M.R. ✓
	• Basements	—	—	—
	b. Width of staircases			
	• Upper Floors	old case	old case	old case ✓
	• Basements	—	—	—
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	old case	old case	old case ✓
3	Compartmentation.			
	• Fire check door	—	—	—

N-6

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	—	—	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	—	—
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 ISI marked	03 ABC type yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30 m 5 mm	02 yes yes	M.R. MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	—	—	—
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	—	—	—

N-7

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pum	—	—	—
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	2500 ltr	2500 ltr	MR
15	Exit Signage.	—	—	—
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	T
19	Fire Control Room			
	• Detector System Panel	—	—	—

N-8

	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer *(Signature)*
 Name N.P. SHARMA
 Designation Asst. Div. offi

ADD
06/12/13

Signature of the Inspecting Officer
 Name
 Designation

