

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001
Ph - 23414333 Fax - 23412593 Email - cfohq.dfire@nic.in

No. FG/DPS/ms/FW/2013/NOZ/1358

Dated 30/12/13

FIRE SAFETY CERTIFICATE

Certified that the Shri Rahul Taneja Fireworks License on Ground floor at Shop No. 1/7784, Main Babarpur Road, East Gorakh Park, Shahdara, Delhi-32, comprised of ground plus one upper floor owned/occupied by M/s Shri Rahul Taneja Fireworks. have complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and verified by the officer concerned of Fire Service on dated 02.12.13 in the presence of Shri Rahul Taneja, and that the Shop No. 1/7784, is fit for occupancy class Fireworks storage with effect from 30/12/13.....for a period of three years, subject to conditions printed overleaf.

Issued on.....30/12/13.....at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer

etc.



Copy to:-

1. The Joint Commissioner of police (Licensing),
1st Floor, P.S. Defence colony, New Delhi.
2. Shri Rahul Taneja, S/o Shri Rajesh Kumar Taneja,
R/o W-5, W-Block, Naveen Shahdara, Delhi-32

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

ADO S. Singh

IRN/1

INSPECTION REPORT

- 1. Name & address of the building : Shri Rahul Taneja Fireworks License at Shop No. 1/7784, Main Babarpur Road, East Gorakh Park, Shahdara, Delhi-32.
- 2. Type of Occupancy : Storage Fireworks
- 3. Type of Case : New Case
- 4. Details of Previous NOC : Nil
- 5. Fire Safety direction letter No :
- 6. Date of Inspection : 27.11.13
- 7. Name of the Inspecting Officers: : ADO Suresh Singh
- 8. Name of the person from the building side : Shri Rahul Taneja
- 9. Year of Construction : 2003
- 10. Reference/Licensing deptt. Letter no. : No. (PFW/19)/2013/63795-97/Joint CP/Lic.(Expl.), dated 21.10.13

S.No	Point of Inspection	Requirement	Provided at Site	Remarks MR/NMR
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9 m ² (min.)	19.81 m ²	MR
	b. Construction	Pucca	Provided	MR
	c. Premises Location	Not under the staircase/Mean of escape	Provided	MR
	d. Business permissible only at ground floor level	Required	Provided	MR
	e. Business from pavement of road prohibited	Prohibited	Yes	MR
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit	Required	Provided (Yes)	MR
3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives/inflammable or hazardous materials.	Required 15 m	Provided	MR
4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purposes	Required	Provided (Yes)	MR
5.	Type of electrical wiring and electrical fitting			
	a. Preferably concealed or through conduit	Required	Provided	MR
	b. All electrical fitting should be flame/spark proof	Required	Provided with Casing & Capping	MR
6.	Extension of shop for business			
	Prohibited	Prohibited	Yes	MR

(Handwritten mark)

JRN/2

Shri Rahul Taneja Fireworks License at Shop No. 1/7784, Main Babarpur Road, East Gorakh Park, Shahdara, Delhi-32

7.	Approach Road			
	The road width on the side of which premises is located should be 12 m	12m	The premises which are approachable by one length hose (30 m) from an abutting road of 12 m	MR
8.	Fire protection arrangements			
	a) Extinguishers (Type & No's.)	2 no. of Water type & 1 no. of ABC/CO ₂ type	Provided	MR
	B) Sand and Water Buckets	2 nos. each	Provided	MR
	C) Water Drum (s)	1 nos.	Provided	MR
9.	Any other point that is contrary to the safety of people.			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh
6.12.13

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO

DO (EAST)

Submitted for approval please

