

(11)

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/School/NO13/W2/1353 Dated: 27/12/2013

FIRE SAFETY CERTIFICATE

Certified that Shree Dwarka Dheesh Public School, Sect-30, Rohini, Delhi-110085 comprised of G + 2 upper floors with School running on 1st floor only owned/occupied by Shree Dwarka Dheesh Dharmik Samiti, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 05/12/2013 in the presence of Sh. Prem Chand Vats and that the building / premises is fit for occupancy of Educational building on first floor only with effect from 27/12/2013 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 27/12/13 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

dca

Copy to:

1. The Principal, Shree Dwarka Dheesh Public School, Sect-30, Rohini, Delhi-110085
2. The Director of Education, Old Sectt. Delhi for information

N-5

new case G+2

INSPECTION REPORT

- 1. Name & address of the building : Shree Dwarka Dheesh Public School, Sect-30, Rohini, Delhi-85
- 2. Type of Occupancy : Educational (G+2) **School running on 1st floor only**
- 3. Type of Case : New Case (GF office and storage, 2nd floor vacant hall)
- 4. Details of previous NOC : Nil
- 5. Fire Safety directives letter No : Director of education
- 6. Date of inspection : 05/12/2013
- 7. Name of the Inspecting Officers : DO(NW)
- 8. Name and designation of officers
from the building side : Sh. Prem Chand Vats
- 9. Year of Construction : 2004
- 10. Applicant's letter No. : S/D/U/P/S/15/13 dated 25/02/2013

PA-350 m² CA-210 Sq.m² CR-5 NOS- 174 NOT- 1+5

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. As dt 01/03/2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	4.5 mtr	P ✓	M/R
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 ✓	02 ✓	M/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.5 mtr	(1) 100cm – 113cm ✓ (2) 150 cm iron s/c upto 1 st floor	M/R
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace	01	01 ✓	M/R
	g. Width of Corridor	--	--	--
	h. Door Size	1 mtr	1 mtr ✓	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	--	--	--
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	--	--	--
	<ul style="list-style-type: none"> • Water Curtain 	--	--	--
	<ul style="list-style-type: none"> • Fire Dampers 	--	--	--
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	--	--
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	--	--
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	06	06	M/R
	<ul style="list-style-type: none"> • Types 	ABC	ABC/CO2	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01 N.R	P	—
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	—	—
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	—	—
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	--	--	--
	<ul style="list-style-type: none"> • Upper Floor 	--	--	--
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	--	--	--
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	--	--	--
	<ul style="list-style-type: none"> • Number of hydrants per floor 	--	--	--
	<ul style="list-style-type: none"> • Hose Box 	--	--	--
12	Yard Hydrants.			

	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	--	--	--
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		N.R	P 450 LPM	—
		—	—	—
		--	--	--
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	--	--	--
		--	--	--
		--	--	--
		--	--	--
		N.R	P 10,000 ltr	—
15	Exit Signage.	--	--	--
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	--	--	--

N-8

18	Refuge Area.			
	➤ Total Area	--	--	--
	➤ Location	--	--	--
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
17/12/13
[Handwritten Initials]