

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

E-mail:- [cfohq.dfire@nic.in](mailto:cfohq.dfire@nic.in)

Fax:- 011-23412593


No. *F6/DFS/ms/2013/2H/52/1373*

Dated: *31/12/13*

**FIRE SAFETY CERTIFICATE**

Certified that the M/s **Laxmi Filling Station (Petrol Pump)** located at G-1, Shopping Centre, Vikaspuri, New Delhi is comprised of ground floor only was issued NOC by this department vide letter No.F.5/(3A)/DFS/2007/268 dated 13.06.2007. The Petrol Pump was re- inspected by the officer concerned of this department on 10.12.2013 in the presence of Sh. Vijay Singh Yadav (Owner) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group J Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....*31/12/2013*.....at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Territory Coordinator (Retail), Delhi,  
Bharat Petroleum Corporation Limited,  
Bijwasan Sansthan, Bijwasan, New Delhi-61.
2. The Manager,  
M/s Laxmi Filling Station, G-1,  
Shopping Centre, Vikaspuri, New Delhi.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Ground floor only

N/7

Renewal

INSPECTION REPORT

1. Name & address of the building : MS Laxmi filling station, G-1, Shopping Centre, Vikaspuri, ND.
2. Type of Occupancy : Group J (Hazardous Building) san
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. FS/(3A)/DFS/2007/268 Date 13/6/2007
5. Fire Safety directives letter No : FS/(3A)/DFS/95/22 dated 13/1/1995
6. Date of inspection : 10/12/2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers  
From the building side : Mr Vijay Singh Yadav (owner)
9. Year of Construction : 1995
10. Applicant's letter No. : RTD. ODD. Fire NOC dated 12-07-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"><li>• Road width</li><li>• Gate width</li><li>• Width of internal road</li></ul>	<p>— — —</p>	<p>09 mtr 06 mtr —</p>	<p>MR MR —</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"><li>• Upper Floors</li><li>• Basements</li></ul>	<p>— —</p>	<p>— —</p>	<p>Ground floor only No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"><li>• Upper Floor</li><li>• Basements</li></ul>	<p>— —</p>	<p>— —</p>	<p>— —</p>
	c. Protection of exits			
	<ul style="list-style-type: none"><li>• Fire check door</li><li>• pressurization</li></ul>	<p>— —</p>	<p>— —</p>	<p>— —</p>
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"><li>• Fire check door</li><li>• Sealing of electrical shafts</li><li>• Fire Rating of shaft door</li><li>• Water Curtain</li><li>• Fire Dampers</li></ul>	<p>— — — — —</p>	<p>— — — — —</p>	<p>— — — — —</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"><li>• Basements</li><li>• Upper floors</li></ul>	<p>30 a/c per hour</p>	<p>— —</p>	<p>No Basement Ground floor only</p>

San



N/C

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	12 No's ABC/CO <sub>2</sub> /Mech foam ISI marked	Provided <del>do</del> <del>do</del>	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	← 30 m 5 mm	— — —	— — —
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	— — — — —	— — — — —	— — — — —
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	— — —	— — —	— — —
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	— — —	— — —	— — —
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	— —	— —	— —
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual stopping</li> </ul>	— — — — — — — —	— — — — — — — —	— — — — — — — —

SAN

M/s Laxmi filling station, G-1, Shopping Centre, Vikaspuri, N.D.  
(Petrol Pump)

2/9

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	—	—	—
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
<b>15.</b>	<b>Exit Signage.</b>	—	—	—
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	— No lift —
		—	—	— do —
		—	—	— do —
		—	—	— do —
		—	—	— do —
<b>17.</b>	<b>Standby power supply</b>	—	15 KVA	—
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	—	—	—

N/10

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to <sup>renewal of</sup> grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings~~ as noted at serial numbers.....

Note :- The Petrol pump premises is comprised of ground floor only. There are Three numbers of "No Smoking" board displayed and ten numbers of sand buckets kept in the premises. FSC is recommended for renewal please

Sandeep  
19/12/2013.

Signature of Inspecting Officer

Name SANDEEP DUGGAL

Designation Asst Divisional Officer

Signature of Inspecting Officer

Name

Designation