

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/schwe/2014/WZ/12

Dated: 02/01/2014

FIRE SAFETY CERTIFICATE

Certified that Ambey Public School, G. No. 59-60, Hanuman Kunj, B-Block, Sant Nagar, Burari, Delhi-110084 comprised of Ground Floor owned / occupied by Ambey Public School has already been issued fire safety certificate vide this office letter No F-6/DFS/MS/2007/2766 dated 27/09/2007. The premise was re-inspected by the officer concerned and observed that the premise is now Ground + one upper floor. The fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have there fore deemed complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 11/12/2013 in the presence of Sh. Sanjay Kumar (Principal) and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 02/01/2013 for a period of three years, subject to compliance of the conditions.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. There will not be more than 45 students in any class room with a single door.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 02/01/14 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

**Copy to:**

1. The Principal, Ambey Public School, G. No. 59-60, Hanuman Kunj, B-Block, Sant Nagar, Burari, Delhi-110084.
2. The Director of Education, Old Secretariat, Delhi – 110054.

G.F. + F.F

INSPECTION REPORT

1. Name & address of the building: AMBEY PUBLIC SCHOOL, GALI NO-59-60, HANUMAN
2. Type of Occupancy: KUNJ, B-BLOCK, SANT NAGAR, BURARI DELHI-84  
Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F.-61.P.F.S./MS/2007/2766 dt- 27-9-07
5. Fire Safety directives letter No: Circular of the director of Education no. 262-382  
DT- 17-10-05
6. Date of inspection: 11-12-13
7. Name of the Inspecting Officers: N.P. Sharma
8. Name and designation of officers  
from the building side: Sanjay Kumar (Principal)  
2005
9. Year of Construction: 2005
10. Applicant's letter No.: 207/013/dt- 20-1-13

PA - 800 sqds. CA - 600 sqds. Nols S - 430, Nols T - 07, Nols CR - 12

	Minimum Standards on fire prevention and fire safety U/R 33	D.O ENBC Requirement <u>dt 17-10-05</u>	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	R	P	MR ✓
	• Upper Floors	01	02	MR ✓
	• Basements	—	—	—
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1 - 1.40 mtr 2 - 0.95 mtr	MR ✓
	• Basements	—	—	—
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	01 mtr	01 mtr	MR
3	<b>Compartmentation.</b>	NIA		
	• Fire check door	—	—	—

N/A

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	-	-	-
4	<b>Smoke Management System.</b>	N/A		
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour	-	-
		12 a/c per hour	-	-
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	one @ 300 smh ISI marked	ou ABC type yes	MR ✓ MR ✓ MR ✓
6	<b>First-Aid Hose Reels.</b>	N/A		
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30 m 5 mm	- - -	- - -
7	<b>Automatic fire detection and alarming system.</b>	N/A		
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	- - - - -	- - - - -	- - - - -
8	<b>MOEFA</b>	-	-	-
9	<b>Public Address System.</b>	-	-	-
10	<b>Automatic Sprinkler System.</b>	N/A		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	- - -	- - -	- - -
11	<b>Internal Hydrants</b>	N/A.		
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	- - -	- - -	- - -
12	<b>Yard Hydrants.</b>	N/A		
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	- -	- -	- -

M/S

13	<b>Pumping Arrangements.</b>	H/A		
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pum</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
14	<b>Captive Water Storage for fire fighting.</b>	N/A		
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
15	<b>Exit Signage.</b>	-	-	-
16	<b>Provision of Lifts.</b>	N/A		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
17	<b>Standby power supply</b>	-	-	-
18	<b>Refuge Area.</b>	N/A		
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-	-	-
		-	-	-
19	<b>Fire Control Room</b>	N/A		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	-	-	-

N/6

	<ul style="list-style-type: none"> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to <sup>Renew</sup> ~~grant~~ Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~ <sup>issued vide letter no. F-6/ DES/MS/2007/2766</sup>

dated 27.09.2007

Signature of the Inspecting Officer 111213

Name N.P. Sharma

Designation A.D.O. 'R'

Signature of the Inspecting Officer

Name

Designation

