

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

Fax : 011-23412593 E-mail : cfhq.dfire@nic.in Ph. 011-23414333.

No.F6/DFS/MS/School/2019/ 2

Dated:---1/1/14---

FIRE SAFETY CERTIFICATE

Certified that the **N.P. Co-Ed. Middle School** located at **Kitchner Road, New Delhi** comprised of **Ground + 1 Upper Floor** was granted NOC by this department vide letter No.**F6/DFS/MS/2010/3391** dated **16/12/10**. The premises was re-inspected & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire/Safety/ 2011/3298 to 3398 dated 01/03/11 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Fire Service on **24/12/13** in the presence of **Mr. Sajjan Kumar (Asstt. Fire Officer)** and that the building / premises is fit for occupancy class **Group 'B' Education Building** with effect from ---1/1/14--- for a period of Three years subject to condition as mentioned below.

Issued on ---1/1/2014--- at New Delhi by.



(Dr.G.C.Misra)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) N.P. Co-Ed. Middle School,
Kitchner Road, New Delhi.

(2) Director of Education,
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. the form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- N.P. Co-Ed. Middle School, Kitchner Road, New Delhi.
2. Type of occupancy:- Group – B Education Building.
3. Type of case:- Renewal.
4. Details of previous NOC:- No.F6/DFS/MS/2010/3391 dated 16/12/10.
5. Fire safety directives No.- N/A as per education circular
6. Date of inspection:- 24/12/13
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer:-
From the building side:- Mr. Sajjan Kumar (Asstt. Fire Officer)
9. Year of construction:- .
10. Applicant's letter No:- Fire/2572 Dated 28/11/13 Ground + 1 Upper floors

Old Case

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | As per Education Circular | Provided at site | Remarks MR/NMR |
|-----------|---|---------------------------|-----------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | Approachable | Provided | MR |
| | 2) Gate width | Required | Provided | MR |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 2Nos. | 2 Nos. | MR |
| | 2. Basements | N/A | N/A | N/A |
| | B. Width of staircase | | | |
| | 1. Upper floors | Required | 1.52 mtr. & 1.08 mtr. | MR |
| | 2. Basements | N/A | N/A | N/A |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | Yes | 1 Nos. | MR |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | 1 mtr. | 1 mtr. | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 a/c per hour | N/A | N/A |
| | 2) Upper floors | 12 a/c per hour | Open corridor | MR |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | ISI Marked | 08 Nos. | MR |
| | 2) Types | | ABC & co2 | MR |
| | 3) ISI marking | | Yes | MR |
| 6. | First-Aid Hose Reel | | | |

M Kaushik

| | | | | |
|------------|---|----------|----------------------|-----|
| | 1) Total number of each floor | NR | 2 Nos. at each floor | MR |
| | 2) Length of hose reel hose | 30 m | Provided | MR |
| | 3) Nozzle diameter | 5 mm | Provided | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | N/A | N/A |
| | 2) Location of main panel | N/A | N/A | N/A |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | N/A | N/A | N/A |
| | 5) Hooter's Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |

| | | | | |
|------------|--|----------|------------|-----|
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | NR | 450 LPM | MR |
| | b) Head of pump | NR | 38 mtr. | MR |
| | c) Power supply | N/A | N/A | N/A |
| | d) Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | NR | 2500 ltrs. | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |

Handwritten signature

| | | | | |
|-----|--|-----|-----|-----|
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

The fire protection system provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/DFS/MS/2010/3391 dated 16/12/10 renewal under rule35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up please

Signature of the inspecting officer

Signature of the inspecting officer

Name :-

Name:- S.S.Kaushik. 26/12

Designation:-

Designation:- Assistant Divisional Officer.

Do South

[Handwritten mark]

Mawoly
26/12