

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE  
Connaught Place: New Delhi-110001  
Ph: 011-23414000; Fax: 011-23412593

No. F.2/DFS/HQRS/ 2036

Dated: 4/7/12

OFFICE ORDER

During the meeting of Fire Prevention Wing on 03.05.2012, the matter regarding the requirement of the width of abutting road for the purpose of issue of permanent fireworks licence was discussed in light of the judgement of Supreme Court of India in I.A. No. 17329/93 and letter No. 28368 dated 11.09.2008 of Addl. Commissioner of Police (Licensing). It has been decided that the premises which are approachable by one length of hose (30 meter) from an abutting road of minimum 12 meter width shall be considered.



Director  
Delhi Fire Service

Distribution :

1. Chief Fire Officer
2. All Divisional Officers/Asstt. Divisional Officers/ Nominated Authorities
3. Computer cell for uploading on website