

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MSI/BNOT/2014/W2/56

Dated: 15/01/2014

Fire Safety Certificate

Certified that the 7 Star Banquet's located at 20, Shivaji Marg (Near Moti Nagar), New Delhi, comprised of Basement, ground floor + one upper floor owned/occupied by 7 Star Banquet's have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 22/12/2013 in the presence of Mr. Tejinder Singh and that the building/premises is fit for occupancy Banquet Hall/Assembly with effect from .....15/01/14...for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Issued on.....15/01/14.....at New Delhi by

  
Santokh Singh  
Chief Fire Officer  
Delhi Fire Service  
E-mail : [cfowzr.dfire@nic.in](mailto:cfowzr.dfire@nic.in)  
Phone : 011-23414250

Copy to:

The Manager

7 Star Banquet's located at 20, Shivaji Marg (Near Moti Nagar), New Delhi



W/11

Basement + ground + 1st floor  
with one room at terrace

1. Name & address of the building : 7 Star Banquet's located at 20, Shivaji Marg (Near Moti Nagar), New Delhi
2. Type of Occupancy : Banquet Hall/Assembly
3. Type of Case : New
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : F6/MS/DFS/BP/2013/2267 dated 19.09.2013
6. Date of inspection : 22.12.2013
7. Name of the Inspecting Officers : DO (West) Sunil Chawdhary
8. Name and designation of officers  
From the building side : Mr. Tejinder Singh
9. Year of Construction :
10. Applicant's letter No. : nil dated 28/11/13

**INSPECTION REPORT**

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	18mtrs	Provided	M.R.
	• Gate width	N.A.	N.A.	N.A.
	• Width of internal road	N.A.	N.A.	N.A.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	3	3	M.R.
	• Basement	2	2	M.R.
	b. Width of staircases			
	• Upper Floors	2 x 2 mtr 1 x 1.5 mtr	1 x 1.5 mtr 2 x 2 mtr	M.R.

	<ul style="list-style-type: none"> <li>Basement</li> </ul>	2 x 2 mtr	Provided	M.R.
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required 2 mtrs	Halls only	M.R.
	f. Door size	2 x 2 mtr	Provided	M.R.
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N.A.	N.A.	N.A.
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	required	Provided	M.R.
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	18	22	M.R.
	<ul style="list-style-type: none"> <li>Types</li> </ul>	Water CO <sub>2</sub>	Provided	M.R.
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ABC & CO <sub>2</sub> Required	Water CO <sub>2</sub> - 6 DCO - 12 CO <sub>2</sub> - 4	
		ISI marks required	provided	M.R.
6.	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	2	provided	M.R.

	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm required	Provided	M.R.
7.	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	N.R.	N.R.	N.R.
8.	<b>MOEFA</b>	Required	Provided	M.R.
9.	<b>Public Address System.</b>	Required	Provided	M.R.
10.	<b>Automatic Sprinkler system</b>	Required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N.R.	N.R.	N.R.
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 mm	Provided	M.R.
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	2	Provided	M.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	2	Provided	M.R.
12.	<b>Yard Hydrants.</b>			

	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>		N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>		N.R.	N.R.	N.R.
<b>13.</b>	<b>Pumping Arrangements.</b>				
	<b>Ground Level</b>				
	➤ Discharge of main pump		NR	NR	NR
	➤ Head of Main pump		NR	NR	NR
	➤ Number of main pumps		NR	NR	NR
	➤ Jockey Pump out put		NR	NR	NR
	➤ Jockey pump head		180 LPM	Provided	M.R.
	➤ Standby pump out put		40 mtr	Provided	M.R.
	➤ Standby pump Head		NR	NR	NR
	➤ Auto Starting/Manual stopping		NR	NR	NR
	➤ Pump Hose Access		NR	NR	NR
	<b>Terrace level</b>				
	➤ Discharge of pump		1620 LPM	Provided	MR
	➤ Head of the pump		40 mtr	Provided	M.R.
	➤ Power supply		Required	Provided	M.R.
	➤ Auto Starting of pump		required	Provided	M.R.
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>				
	<b>Underground tank capacity</b>		25,000 ltrs	Tank provided on terrace	N.R.
	➤ Draw -off connection		N.R.	N.R.	N.R.

	➤ Fire service inlet		N.R.	N.R.	N.R.
	➤ Access to tank		N.R.	N.R.	N.R.
	➤ Overhead Tank Capacity		N.R.	25,000 ltrs O.H. tank provided instead of U.G tank	M.R.
15	<b>Exit Signage.</b>		Required	Provided	M.R.
16.	<b>Provision of Lifts</b>				
	• Pressurization of Lift Shaft		N.A.	N.A.	N.A.
	• Pressurization of Lift lobby		N.A.	N.A.	N.A.
	• Communication In lift Car		N.A.	N.A.	N.A.
	• Fireman's Grounding Switch		N.A.	N.A.	N.A.
	• Lift Signage		N.A.	N.A.	N.A.
17.	<b>Standby power supply</b>		Required	Provided	M.R.
18.	<b>Refuge Area</b>				
	➤ Total Area		N.R.	N.R.	N.R.
	➤ Location		N.R.	N.R.	N.R.
19.	<b>Fire Control Room</b>		N.R.	N.R.	N.R.
	➤ Detector System Panel		N.R.	N.R.	N.R.
	➤ Flow Switch Panel		N.R.	N.R.	N.R.
	➤ PA system Panel		N.R.	N.R.	N.R.
	➤ Batter backup		N.R.	N.R.	N.R.
	➤ Building Floor plans		N.R.	N.R.	N.R.

20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N.R.	N.R.	N.R.
-----	---	------	------	------

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

Signature of the Inspection Officer

Name Sunil Chawdhary

Signature of the Inspection Officer

Name