

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in

No F6/DFS/MS/School/2014/MOZ/60

Dated: 16/01/14

FIRE SAFETY CERTIFICATE

Certified that the **Asian Public School at, Ranjit Singh Marg, Meer Dard Road, New Delhi-110002** comprises of ground floor and school running at ground floor only have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 & DFS order dated 18.04.2012 and verified by the officer concerned of Fire Service on 27-09-2013 in the presence of Mrs. Sanobar Khanam (Principal) of the school and that the building is fit for occupancy, class B "Educational Building" with effect from ~~16/01/~~ 2014 for a period of **three years**, subject to conditions printed overleaf.

Issued on16/01/14..... at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. Asian Public School at, Ranjit Singh Marg, Meer Dard Road, New Delhi-110002

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of Unauthorized construction, if any.

1/11

INSPECTION REPORT

1. Name & address of the building : Asian Public School, Ranjit Singh Marg, Meer Dard Road, New Delhi-110002
2. Type of Occupancy : Educational (Gr.floor)
3. Type of Case : Fresh
4. Details of previous NOC : NA
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 27/09/2013
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Mrs. Sanobar Khanam (Principal)
- 9 Year of Construction :
10. Applicant's letter No. : Letter No.- Nill dated 24.10.2013.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	12 Mtr.	MR
	• Gate width	4 Mtr.	4 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c..Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

h

Mesh

N/2

	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.2 Mtr.	1.2 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	4 Nos.	6 Nos.	MR
	• Types	ABC & Co ₂	ABC & Co ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	NA	NA	NA
	• Head of the pump	NA	NA	NA
	• Power supply	NA	NA	NA
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage			
		NA	NA	NA
16	Provision of Lifts			

h
mesh

N/h.

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under Director Education circular dated 01.03.2011 to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.



Do (CD)

8/1/14

Signature of the Inspecting Officer

Mesha
8/1/14

Name :- M.K. Sharma
Designation :- A. D.O. (CC)

