

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2014/W2/217

Dated: 12/02/14

FIRE SAFETY CERTIFICATE

Certified that the **Shah International School**, at **Kansi Ram Shah Marg, Ambica Vihar, Pashim Vihar, New Delhi-110087** comprised of **Ground + One floor** only owned / occupied by **Shah International School** was earlier issued NOC / FSC by this department vide letter No. **F.6/DFS/MS/2010/1792** dated **18.06.2010**. The premises was re-inspected by the officer concerned of this department on **30.01.2014** in the presence of **Sh. Surender Kumar Shah (Chairman)** and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by **Director of Education, GNCT of Delhi** vide letter No. **262-362** dated **17.01.2005** and that the building / premises is fit for occupancy Educational (Group B) with effect from 12/02/14.....for a period of 3 (three) years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 12/02/14 at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250
E-mail: cfowz.dlfire@nic.in

Copy to :-

1. Sh. Surender Kumar Shah (Chairman), Shah International School, Kansi Ram Shah Marg, Ambica Vihar, Pashim Vihar, New Delhi-110087.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

N/A

G+1

INSPECTION REPORT

1. Name & address of the building: Shah International School, Kanshi Ram Shah Marg, Ambica Vihar, Paschim Vihar, New Delhi-110087.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/2010/1792 dated 18.01.2010
5. Fire Safety directives Letter No. : DOE Circular Dated 17.01.2005
6. Date of inspection : 30.01.2014
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer
from the building side : Sh. Surender Kumar Shah (Chairman)
9. Year of Construction : 1995
10. Applicant's letter No. : Nil dated 15.01.2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/ <u>DOE</u> <u>Cir.17.1.2005</u> Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	
	• Basements	Nil	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.60 Mtr.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.00 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.00 Mtr.	Provided	MR

3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	12	14	MR
	• Types	ABC/Co2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	One at each floor	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 MM	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	NR	NR	NR
	• Upper Floor / GF	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR

11. Internal Hydrants				
	• Size of riser/down- comer	100 MM	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	One	Provided	MR
12. Yard Hydrants				
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13. Pumping Arrangements				
	• Ground Level / Over Head			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	220 LPM	Provided	MR
	➤ Head of the pump	40 Meter Head	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14. Captive water Storage for fire fighting				
	• Under ground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	2500 Ltr.	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Batter backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2010/1792 dated 18.01.2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Contd
on N/8

N^o 8
Shah International School, Ambika Vihar,
Paschim Vihar, New Delhi - 110087

AK Jaiswal
30/1/2014

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

(A. K. JAISWAL)

Name

Designation

ADO (Jwalapur)

Designation