

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333

NO.F6/DFS/MS/ 2014/SZ/72

Dated: 17/01/14

FIRE SAFETY CERTIFICATE

Certified that M/s **Third Eye Discotheque (A Unit of Ratna Vacations (P) Ltd.)** located at ground floor of S1 Hotel Intercontinental Eros, Nehru Place, New Delhi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officers concerned of Delhi fire service on 13.01.2014 in presence of Shri Anil Kumar Sharma (Manager, Fire & Safety) and that the building/premises is fit for occupancy class **(Assembly-Discotheque)** with effect from 17/01/14 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/01/14 at New Delhi by.



(Dr. G.C. Misra)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Third Eye Discotheque, A Unit of Ratna Vacations (P) Ltd., S1Hotel Intercontinental Eros, Nehru Place, New Delhi.
2. The Dy. Health Officer, Central Zone, SDMC, Jal Vihar, Lajpat Nagar, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

17/6

INSPECTION REPORT

1. Name & address of the building : Third Eye Discotheque (A Unit of Ratna Vacations (P) Ltd.), at S1Hotel Intercontinental Eros, Nehru Place, New Delhi.
2. Type of Occupancy : Assembly
3. Type of Case : New case
4. Details of previous NOC : nil
5. Fire Safety directives letter No. : N/A
6. Date of inspection : 13.01.2014
7. Name of the Inspecting Officers : M.K.Chattopadhyay ADO(M.Rd), D.B. Mukherjee ADO(Nehru Place)
8. Name and designation of officers
from the building side : Mr. A.K. Sharma (Manager Fire & Life Safety)
9. Year of Construction : 1994
10. Applicant's letter No. : DHO/Cen.Z/2014/1915 dated 10-01-2014

The Third Eye Discotheque (A Unit of Ratna Vacations (P) Ltd.) is located at ground floor of S1 Hotel Intercontinental Eros, Nehru Place, New Delhi

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	Provided	MR
	• Gate width	06 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	Located at GF	-	-
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	Located at GF	-	-
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	2.0 mts	Provided	MR
	h. Door Size	2 mts	2.0 mts, 1.10 mts Provided	MR

A

ly

N/A

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	06	Provided	MR
	<ul style="list-style-type: none"> • Type 	ABC, CO ₂ type	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	02	Provided both side of the Discotheque	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided both side of the Discotheque	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided both side of the Discotheque	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	Provided in entire hotel bldg.		
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required	Provided	MR
11	Internal Hydrants	Provided in entire hotel bldg.		
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	Provided both side of the Discotheque	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	02	Provided both side of the Discotheque	MR
	<ul style="list-style-type: none"> • Hose Box 	02	Provided both side of the Discotheque	MR
12	Yard Hydrants.	Provided in hotel bldg.		

N/A

N/A

178

	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	Provided.	---
		N/A	Provided.	----
13	Pumping Arrangements. Provided for entire hotel bldg.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-	-	-
		Not required	2800 LPM (hotel bldg) provided	----
		Not required	115 mts provided	----
		Not required	02 nos provided for hotel bldg.	----
		Not required	402 LPM Provided hotel bldg.	----
		Not required	115 mts	----
		Not required	2800 LPM (hotel bldg) provided	----
		Not required	115 mts.	----
		N/A	N/A	N/A
		----	----	----
		450 LPM	Provided	MR
		80 mts	Provided	MR
		Required	Provided.	MR
		Required	Provided	MR
		----	----	----
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	4,00,000 lts Provided for entire hotel bldg.	----
		N/A	Provided for hotel bldg.	----
		N/A	Provided for hotel bldg.	----
		N/A	Provided for hotel bldg.	----
		10,000 lts	32,000 lts Provided for entire hotel bldg.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	Required	Provided (DG set 1000 KVA X 3)	MR

79

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	Provided for hotel bldg.	----
	• Flow Switch Panel	N/A	Provided for hotel bldg.	----
	• PA System Panel	N/A	Provided for hotel bldg.	----
	• Batter backup	N/A	Provided for hotel bldg.	----
	• Building Floor Plans	N/A	Provided for hotel bldg.	----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	ABC type fire extinguisher provided near Elect. Panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

DFA is put up for approval & signature please.



D.B.MUKHERJEE
ADO (BCP)

[Handwritten signature]

[Handwritten signature]
13/1/14

M.K.CHATTOPADHYAY
ADO (M.Road)