

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


No F 6 / DFS / MS / School / 2014 / SW / 79

DATED 20/01/14

FIRE SAFETY CERTIFICATE

Certified that the The Fun Valley School at RZ – H -921 Gali No. 14, Raj Nagar – II, Palam Colony, New Delhi having two blocks comprised of ground and ground plus one upper floor owned / occupied by The Fun Valley School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F 16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate Of Education, Govt. of NCT of Delhi and verified by the officer concerned of Fire Service on 13.01.2014 in the presence of Sh Ravi Solanki (Manager) and that the building / premises is fit for occupancy class Group ' B' Educational with effect from 20/01/14 for a period of 3 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to Compliance of the conditions under rule 38 of the delhi fire service rules,2010.

Issued on 20/01/14 at New Delhi.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
(Ph. 011 – 23414333)

Copy to:-

1. The Director of Education
Government of NCT of Delhi
2. The Manager,
Fun Valley School,
RZ –H- 921, Gali No 14, Raj Nagar – II Palam Colony, New Delhi

Conditions:

1. All the mean of escape/ entry/ exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system / equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of delhi fire service 2010. the form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	The Fun Valley School, RZ-H-921, Gali No. 14, Raj Nagar-II, Palam Colony, New Delhi.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	New	
4	Details of previous NOC	No.	
5	Fire safety directives letter No	Edu.Circular No.F.16/Estate/CC/Fire Safety/2011/3298 Dated. 01.03.2011	
6	Date of inspection	13.01.2014	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Ravi Solanki (Manager)	
9	Year of construction	2009	
10	Applicant's letter No.	Nil Dated. 12.12.2013	(Having 02 blocks Ground & Ground plus one upper floor)

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Approachable FE	6 Mtr Provided	MR
	2) Gate width	N/A	02 Mtrs.	N/A
	3) Width of internal road	6 Mtrs.	6 Mtrs.	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs. Divided in to two	M/R
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs. Divided in to two	M/R
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	1.25 Mtrs.	N/A
	f. Door size	1 Mtr.	1 Mtr Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
	upper floors	12 a/c per hour	Natural Vent.	M/R
5	Fire Extinguishers			
	Total numbers	CO2, 2.5 Kg or ABC	04 Nos	M/R
	Types	01 for 300 Sq. Mtrs, (ISI Marked)	ABC	M/R
	ISI marking		Provided	M/R

6	First-Aid Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/3

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area	-	-	-
	location	-	-	-
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Required	Provided ABC	M/R

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for your approval and signature please.

S.P. Bhardwaj
15/1/14

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)