

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/2014/W2/34

Dated: 10/01/14

FIRE SAFETY CERTIFICATE

Certified that the **St. Mathew's School** located at **A - 6, Paschim Vihar, New Delhi - 110069** comprised of Ground plus Three Upper Floors was issued FSC vide letter no. F.6/DFS/MS/2009/503 dated 18-02-2009. The premises was re inspected by the officer concerned of this department on 24-12-2013 in the presence of Mrs. Anita Sethi (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from 10/01/14... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/01/14.... at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Mrs. Anita Sethi (Principal),
St. Mathew's School,
A - 6, Paschim Vihar, New Delhi - 110069

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Reinspection to see compliance of shortcomings communicated vide letter no F.6/DFS/MS/2013/5/1972 dated 08-08-13.

INSPECTION REPORT

1. Name & address of the building: St. Mathew's Public School,
A-6, Paschim Vihar, New Delhi-63
2. Type of Occupancy : Educational (School) (4+3 upper floors)
3. Type of Case : Renewal (30 Rooms)
4. Details of previous NOC : Letter No. F.6/DFS/MS/2009/503 dated 18/2/09
5. Fire Safety directives Letter No. : DOE F.16/Esttate/CC/Pun/Hq/2011/3298-3398
6. Date of inspection : 24-12-13
7. Name of the Inspecting Officer : Mukesh Verma ADO(MN)
8. Name and designation of Officer from the building side : Mrs. Anita Sethi
(Principal)
9. Year of Construction : 2005
10. Applicant's letter No. : -----

Total Area = 6069.88m², Covered Area = 2854.39m²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	4	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old case	Old case	Old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	2x110 cms	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 @ 300m ² ABC & CO ₂ ISI marked	Provided Provided Yes	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 30m 5mm	Provided & functional Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8.	MOEFA		N/A	
9.	Public Address System		N/A	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 		N/A	

11.	Internal Hydrants			
	• Size of riser/down-comer	NR	Provided	MR
	• Number of hydrants per floor	NR	Provided	MR
	• Hose Box	NR	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants		N/A	
	• Hose Box			
13.	Pumping Arrangements			
	Ground Level			
	• Discharge of main pump			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm & 180 lpm Provided & functional	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity			
	➤ Draw of connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity	5000 lts.	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage		N/A	
17.	Standby power supply		N/A	
18.	Refuge Area			
	➤ Total area			
	➤ Location		N/A	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel		N/A	

2/17.

	<ul style="list-style-type: none"> ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 			
20.	Special Fire Protection Systems for Protection of special Risks, if any;			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F. 6/DPS/MS/2009/503 dated 18-02-09 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer *Mukesh Verma 20/2/13*

Name *Mukesh Verma*

Designation *ADO (MN)*

Signature of the Inspecting Officer

Name

Designation

