

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014/school/w2/ 82

Dated: 20/01/2014

FIRE SAFETY CERTIFICATE

Certified that the Srijan Shiksha Samiti , 46, Nai Basti Bankner, Narela, Delhi-110040 comprised of Ground floor only owner / occupied by Srijan Shiksha Samiti was issued fire safety certificate vide letter No F-6/DFS/MS/2011/338 dated 18/02/2011. The premises was re-inspected by the officer from this department on dated 16/12/2013 in the presence of Smt. Parveen (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 20/01/2014 for a period of three years, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 20/01/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Srijan Shiksha Samiti, 46, Nai Basti Bankner, Narela, Delhi-110040
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building: Small Wonder School (Smijan Shiksha Samite)
46, Bankmeer Narela del h-40
2. Type of Occupancy: Edu.
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F.O./D.F.S./MS/2011/338 dt-18-2-2011
5. Fire Safety directives letter No: Dir. # Edu. circular dt-17-1-05
6. Date of inspection: 16-12-13
7. Name of the Inspecting Officers: APD (SW)
8. Name and designation of officers from the building side: Principal, Praveen
9. Year of Construction: 2002
10. Applicant's letter No.: SSSBN/04/13 dt-23-9-13

PA-300m² CA 240m² NOCR-7 NOS-135

	Minimum Standards on fire prevention and fire safety U/R 33	DOENBC Requirement <u>with dt-17-1-05</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible one hose length</u>	<u>M/R</u> ✓
	• Gate width	<u>—</u>	<u>—</u>	<u>—</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>—</u>	<u>—</u>	<u>—</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	b. Width of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>—</u>	<u>—</u>	<u>—</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>—</u>	<u>—</u>	<u>—</u>
	g. Width of Corridor	<u>—</u>	<u>—</u>	<u>—</u>
	h. Door Size	<u>old case</u>	<u>old case</u>	<u>old case</u> ✓
3	Compartmentation.			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>

N/4

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	3 ABC ISI marked	3 ABC	MR ✓ MR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		N/A	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		N/A	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 	N/A		
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A		
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A		
17	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 			

	<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ^{Renew} ~~grant~~ Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue~~ ~~shortcomings~~ ~~as~~ ~~noted~~ ~~at~~ ~~serial~~ ~~numbers~~..... ~~N/A~~..... ~~earlier~~..... *issued via letter no N-6/OFS/MS/2011/373 dated 18.2.11*

Signature of the Inspecting Officer

Name

Designation

DD (N/O) Singh

Signature of the Inspecting Officer

Name

Designation

DD (N/O) 25/12/11

ADD (B/O)

