

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2014 / *school/w2/110*

Dated: *28/01/2014*

FIRE SAFETY CERTIFICATE

Certified that Shivani Convent School, 266, Gali no.-10, Samay pur, Delhi-110042 comprised of Ground + 2 upper floor owned/occupied by Shivani Convent School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2008/41 dated 08/01/2008 The premises was re-inspected by the officer from this department on dated 15/01/2014 in the presence of Sh. Beer Singh Yadav and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 28/01/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 28/01/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Shivani Convent School, 266, Gali no.-10, Samay pur, Delhi-110042.
2. The Director of Education, Old Secretariat, Delhi.

G.F + Two upper floors

INSPECTION REPORT

1. Name & address of the building: Shivani Convent School, 266, Gali No-10
Samaypur Delhi. Educational
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/DFS/MS/2008/41 dt 08-01-08
5. Fire Safety directives letter No: Director of Education
6. Date of inspection: 15-1-14
7. Name of the Inspecting Officers: N.P. Sharma
8. Name and designation of officers
from the building side: Sh. B. Singh Yadav
9. Year of Construction: 2004-05
10. Applicant's letter No.: S.C.S.13/265 dt 26-12-13

Plot area:- 2553yds Covered area:- 7105yds No.'s of students:- 298 No's of classrooms:- 09.

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	P	MR
	• Basements	—	—	—
	b. Width of staircases			
	• Upper Floors	old case	old case	old case
	• Basements	—	—	—
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1mth	1.10mth	MR
3	Compartmentation.			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—

4	Smoke Management System.			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	06	06	MR
	• Types	ISI marked	ABC	MR
	• IS marking		yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	one at each floor	03	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5 mm	P	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA			
9	Public Address System.			
		—	—	—
10	Automatic Sprinkler System.			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	R	P	MR
	• Number of hydrants per floor	R	P	MR
	• Hose Box	R	P	MR
12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—

M/15

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 	450 lpm	P	MR
		40 mtr	P	MR
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
		5000 ltr	5000 ltr	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F...6/D.F.S./MS/2008/41 Dated..08/10/11/2011 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer *N.P. Sharma* 15-01-14

Name **N.P. SHARMA**

Designation **ADD 'R'**

Signature of the Inspecting Officer

Name

Designation

CFo/105
21/1/14