

07 copy

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: cfohq.dlfire@nic.in , Tel:- 011-23414333

No. F6/MS/DFS/Club/2014/ 52/33

Dated 10/01/14

FIRE SAFETY CERTIFICATE

Certified that the Safdarjung Club located at Safdarjung Enclave, New Delhi-110029, comprised of Basement, Ground + Two Upper Floors, was granted FSC by this department vide letter NO.F6/DFS/MS/Club/2010/3450 Dated-31/12/2010. The club was re-inspected by the officer concerned of this department on 27/12/13 in the presence of Mr.Binay Kumar Jha, Dy. Admin. Officer and found that the said club have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Group – D Assembly Building with effect from ~~10/01/14~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~10/01/14~~ at New Delhi by.


G.C.
(Dr. G.C. Misra)
Chief Fire Officer

Copy to:-

1. Mr. Binay kumar Jha
Deputy Administrative Officer
Safdarjung Club,
New Delhi-110029

07c
8/1/14
ADD (B.L.P.)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Safdarjung Club, Safdarjung Enclave, New Delhi-110029
2. Type of occupancy:- Assembly (Club)
3. Type of case:- Renewal
4. Details of previous NOC:-F6/DFS/MS/Club/2010/3450 Dated-31/12/2010
5. Fire safety directives No.-F6/DFS/MS/90/258 Dated:27-02-1990
6. Date of inspection:-27/12/13
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Binay Kumar Jha
9. Year of construction:- 1973.
- 10.Applicant's letter No:-SJC/Fire NOC/2013 dated 25/11/13,

The building is comprised of Basement, Ground + Two Upper Floors (Old case)

S.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	Provided	MR
	2) Gate width	Required	Provided 04 gates having width of 4.20 m, 3.67 m 3.78 m & 1.94 m respectively	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Required	2nos	MR
	2. Basements	Required	2nos	MR
	B. Width of staircase			
	1. Upper floors	Required	1.36mtrs & 0.90mtrs	MR (Old Case)
	2. Basements	Required	1.36mtrs & 0.90mtrs	MR(Old Case)
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	Provided 02nos	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fans	MR
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	25Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR

E

6.	First-Aid Hose Reel			
	1) Total number of each floor	One	Provided	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided in restaurant	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	N/A	N/A
	2) Number of hydrants per floor	01	N/A	N/A
	3) Hose box	01	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	Required	22.5m 40m	MR
	c) Power supply	Required	DG SET	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5000 L	10000 L	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A


17.	Stand by Power Supply	Required	DG Set 160 Kva ,62.5Kva	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures are required under the rules the Noc is issued vide letter no F6/DFS/MS/CLUB/2010/3450 Dated-31/12/2010.renewal under rule 35of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature if approved.

Signature of the inspecting officer



2/1/2014

Name :- D.B. Mukherjee.

Designation :-Assistant Divisional Officer.