

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No. F.6/DFS/MS/School/2014/ 52 /123

Dated: 29/01/14

**FIRE SAFETY CERTIFICATE**

Certified that the **Red Rose Model School** located at WE- 43,44 & 45, Mohan Garden, Rama Park Road, New Delhi-110059 is comprised of Ground floor plus two upper floors was issued NOC by this department vide letter No.F.6/DFS/MS/2010/2695 dated 17.09.2010. The School building was re- inspected by the officer concerned of this department on 16.01.2014 in the presence of Smt. Alka Aggarwal (Principal) and found that the New Anand Welfare & Educational Society (Regd.) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....29/01/14..... at New Delhi.



(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Principal,  
Red Rose Model School,  
WE-43,44 & 45, Mohan Garden,  
Rama Park Road, N.D-110059.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110 054.

06

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on **[www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)**

Ground floor, first floor and second floor

N/3

Renewal

INSPECTION REPORT

1. Name & address of the building : Red Rose Model School, WF-43, 44, 45 Mohan Garden, Rama Park Rd. NO-57
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. FG/DFS/MS/2010/2695 Date 17/09/2010
5. Fire Safety directives letter No : \_\_\_\_\_
6. Date of inspection : 16.01.2014
7. Name of Inspecting Officer : ADG Sandeep Duggal
8. Name and designation of officers  
From the building side : Smt Alka Aggarwal (Principal)
9. Year of Construction : 2002
10. Applicant's letter No. : Nil dated 19.09.2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p>Accessible</p> <p>—</p> <p>—</p>	<p>06 mty</p> <p>260, 130 &amp; 130 cms</p> <p>—</p>	<p>MR</p> <p>—</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p>—</p> <p>—</p>	<p>Two numbers</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p>—</p> <p>—</p>	<p>132 &amp; 87 cms</p> <p>—</p>	<p>MR</p> <p>No Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>	<p>—</p> <p>—</p>
	d. No. of continuous staircases to terrace			
		<p>—</p>	<p>one</p>	<p>—</p>
	e. Width of Corridor			
		<p>—</p>	<p>365 &amp; 136 cms</p>	<p>MR</p>
	f. Door Size			
		<p>—</p>	<p>Two nos (86 cms each)</p>	<p>—do</p>
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>	<p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<p>30 a/c per hour</p> <p>—</p>	<p>—</p> <p>Natural Ventilation</p>	<p>No Basement</p> <p>MR</p>

Sam

N/A

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	08 Nos	provided	MR
	• Types	ABC & CO <sub>2</sub>	<del>do</del>	MR
	• IS marking	ISI marked	<del>do</del>	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	one	provided	MR
	• Length of hose reel hose	30 m	<del>do</del>	MR
	• Nozzle diameter	5 mm	<del>do</del>	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8.	MOEFA			
9.	Public Address System			
			provided	—
10.	Automatic Sprinkler System			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11.	Internal Hydrants			
	• Size of riser/down-comer	—	100 mm	—
	• Number of hydrants per floor	—	one per floor	—
	• Hose Box	—	<del>do</del>	—
12.	Yard Hydrants			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/Manual stopping	—	—	—

N/S  
 Red Rose Model School, WE 43, 44, 45 Mohan Garden,  
 Rama Park Road, ND-59

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	—	—	—
		450 & 180 lpm	provided	MR
		40 mhp	— do —	MR
		—	—	—
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
		—	—	—
		—	provided (Two way)	MR
		—	—	—
		5000 ltr	provided	MR
15.	<b>Exit Signage.</b>	Required	provided	MR
16.	<b>Provision of Lifts.</b>			No lift
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17.	<b>Standby power supply</b>	—	62.5 KVA	—
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	—	—	—

*Sas*

