

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in

No F6/DFS/MS/School/2014/M02/59

Dated: 16/01/14

FIRE SAFETY CERTIFICATE

Certified that the **NP Girls, Sr. Sec. School at, Gole Market, New Delhi** comprises of ground floor & a hall was granted NOC by this department vide letter No. F6/DFS/MS/GH/09/3217 dated 04-11-2009. The premises was re-inspected by the officer concerned of this department on 19-09-2013 in the presence of Mrs. Rama Sharma (Principal) and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 & DFS order dated 18.04.2012 and that the building is fit for occupancy of class B "Educational Building" with effect from 16/01/14 2014 for a period of three years, subject to conditions printed overleaf.

Issued on16/01/14..... at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. NP Girls, Sr. Sec. School at, Gole Market, New Delhi
2. Fire Officer NDMC- Letter Nill dated 10.09.2013

ok
M

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of Unauthorized construction, if any.

N/3

INSPECTION REPORT

1. Name & address of the building : NP Girls Sr. Sec. School, Gole Market, New Delhi.
 2. Type of Occupancy : Educational (Gr. & Hall)
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/09/3217 dated 04/11/2009
 5. Fire Safety directives Letter No. : NA
 6 Date of inspection : 19/09/2013
 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
 8 Name and designation of Officer
 from the building side : Mrs. Rama Sharma (Principal)
 9 Year of Construction : 2009
 10. Applicant's letter No. : Fire Officer NDMC- Letter No.- Nill- dated 10.09.2013

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	9 Mtr.	MR
	• Gate width	4 Mtr.	4 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 Mtr.	1.5 & 1.25 Mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

h

Merls

N/4.

M

	d. No of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width Of Corridor	1 Mtr.	1 Mtr.	MR
	f. Door Size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	12 Nos.	16 Nos.	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	YES	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	05	05	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

h

N/5

11	Internal Hydrants			
	• Size of riser/down- comer	100 MM	100 MM	MR
	• Number of hydrants per floor	2 No. each floor	2 No. each floor	MR
	• Hose Box	2 No. each floor	2 No. each floor	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	450 LPM & 220 LPM	450 LPM & 220 LPM	MR
	• Head of the pump	30 Mtr.	30 Mtr.	MR
	• Power supply	YES	Provided	MR
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	YES	Provided	MR
	• Overhead Tank capacity	5000 ltr.	5000 ltr.	MR
15	Exit Signage	YES	Provided	MR
16	Provision of Lifts			

by


Mash

N/G

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/09/3217 dated 04/11/2009 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



~~Do (CD)~~

Signature
8/1/14

Signature of the Inspecting Officer

M.K. Sharma
6/11/14

Name :- M.K. Sharma

Designation :- A. D.O. (CC)