

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

**Fax : 011-23412593 E-mail : [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in) Ph. 011-23414333.**

No.F6/DFS/MS/2014/ *hospital/sz/119*

Dated :-----*28/01/2014*

**FIRE SAFETY CERTIFICATE**

Certified that the **Nehru Homeopathic Medical College & Hospital** located at **B-Block, Defence Colony, New Delhi-110024**, comprised of **3 blocks Main Block -Ground + 3 Upper Floors, Admin Block -Ground + 3 Upper Floors & Teaching Block -Ground + 2 Upper Floors** owned/occupied by **Nehru Homeopathic Medical College & Hospital (GNCT of Delhi)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verify by the officer concerned of fire service on **13/01/14** in the presence of **Mr. G.L. Suberwal AE (EL) & Mr. Brijkishor JE (EL)** and that the premises fit for occupancy class **Institutional Building** with effect from-----*28/01/14*---for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued ---*28/01/14*-----at New Delhi by.

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to:- (1) Head of Office, Nehru Homeopathic Medical College & Hospital,  
GNCT of Delhi, B-Block, Defence Colony, New Delhi-110024.

(2) Executive Engineer (E),  
PWD Elect. Maint. Divn. M-453, MSO Building,  
11<sup>th</sup> Floor, New Delhi-110002.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

- N/3 -

**INSPECTION REPORT**

1. Name & address of the building:- Nehru Homeopathic Medical College & Hospital,B-Block,Defence Colony,New Delhi-110024.
2. Type of occupancy: - Institutional Building.
3. Type of case:- New
4. Details of previous NOC:- No.
5. Fire safety directives No.-
6. Date of inspection:- 13/01/14
7. Name of the inspecting officer:- D.O. D.P. Bharadwaj & A.D.O. S.S. Kaushik
8. Name & designation of officer  
From the building side:- Mr. G.L. Suberwal AE (El.) & Mr. Brijkishor JE (El.).
9. Year of construction:- 1969 & Teaching block 2010
10. Applicant's letter No:- F2(277)/NHMC/2012/3074-81 dated 18/12/13 **3 blocks Main Block -Ground + 3 Upper Floor ,Admin Block -Ground + 3 Upper Floor & Teaching Block - Ground + 2 Upper Floor.**

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC /BBL Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	16 mtr.	Provided	MR
	2) Gate width	4 mtr.	Provided	MR
	3)Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	Required one & four	Teaching block 1 Nos. ,Main & Admin block 4 Nos.	MR old building
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	Required	Teaching block 1.75 mtr. main & admin block 1.10 mtr.,1.30 mtr X 2 & 2 mtr.	MR old building
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	3 Nos.	3 Nos.	MR
	E. Width of corridor	Required	1.5 mtr.	MR
	F. Door size	1.5 mtr.	1.5 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A

*(Handwritten signature)*

- N/6 -

4.	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	open corridor/window	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	89 Nos.	MR
	2) Types		ABC & W.Co2 & CO2	MR
	3) ISI marking		Yes	MR
6.	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	Required	1 Nos. in teaching bock, 4 Nos. in main & admin bock	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Smoke detector	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Yes	Provided	MR
	5) Hooter's Location	All floors	Provided	MR
8.	<b>MOEFA</b>	Yes	Provided	MR
9.	<b>Public Address System</b>	Yes	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	Required	150 mm.	MR
	2) Number of hydrants per floor	4 + 1 Nos.	5 Nos.	MR
	3) Hose box	4 + 1 Nos.	5 Nos.	MR
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	12 Nos.	12 Nos.	MR
	2) Hose box	12 Nos.	12 Nos.	MR

37

13.	<b>Pumping Arrangement</b>			
	1) Ground level			
	a) Discharge of main pump	1620 LPM	1620 LPM	MR
	b) Head of main pump	60 mtr.	60 mtr.	MR
	c) Number of main pump	One	One	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	60 mtr.	60 mtr.	MR
	f) Stand by pump output	1620 LPM	1620 LPM	MR
	g) Stand by pump head	60 mtr.	60 mtr.	MR
	h) Auto starting/Manual stopping	Yes	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	1,00,000 ltrs.	1,00,000 ltrs.	MR
	a) Draw-off connection	Yes	Provided	MR

	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	Yes	Provided	MR
	d) Over head tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15.	<b>Exit Signage.</b>	Yes	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Yes	Provided	MR
	d) Fireman's switch	Yes	Provided	MR


	e) Lift signage	Yes	Provided	MR
17.	<b>Stand by Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Yes	Provided	MR
	d) Battery backup	Yes	Yes	MR
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up please

Signature of the inspecting officer



Name:- D.P. Bharadwaj

Designation:- Divisional Officer

Signature of the inspecting officer



Name:- S.S. Kaushik.

Designation:- Assistant Divisional Officer