

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in


No F6/DFS/MS/School/2014/MOZ/102

Dated: 24/01/14

**FIRE SAFETY CERTIFICATE**

Certified that the **MCD Boys School Rouse Avenue-II, New Delhi** having two shifts (1<sup>st</sup> and 2<sup>nd</sup>) comprises of ground floor and school running at ground floor was granted NOC by this department vide letter No.F6/DFS/MS/2007/1296 dated 08/05/2007. The premises was re-inspected by the officer concerned of this department on 27-09-2013 in the presence of Mr. Khurshid Ahmed (Head Master) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 & DFS order dates 18-04-2012 and that the building is fit for occupancy, class B "Educational Building" with effect from 24/01/2014 for a period of **three years**, subject to the condition printed overleaf.

Issued on ...24/01/14..... at New Delhi by.



(Dr. G. C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph – 011-23414333

Copy to:-

1. MCD Girls School 1<sup>st</sup> Shift at Rouse Avenue-II, New Delhi
2. MCD Boys School 2<sup>nd</sup> Shift at Rouse Avenue-II, New Delhi
3. The Director Education, Old Secretariat, Delhi – 110054.
4. The Director Education, MCD, Nigam Bhavan, Kashmere Gate, Delhi.

ofc  
New

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of Unauthorized construction, if any.

N/6

**INSPECTION REPORT**

1. Name & address of the building : MCD Boys School 2<sup>nd</sup> shift at, Rouse Avenue-II, New Delhi.
2. Type of Occupancy : Educational Gr. Floor (1<sup>st</sup> shift & 2<sup>nd</sup> shift)
3. Type of Case : **Renewal**
4. Details of previous NOC : F6/DFS/MS/2007/1296 dated 08/05/2007
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 27/09/2013
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer  
from the building side : Mr. Khurshid Ahmed (Head Master)
- 9 Year of Construction : old
10. Applicant's letter No. : Letter No. Nill dated 10-02-2012

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	12 Mtr.	<b>MR</b>
	• Gate width	4 Mtr.	4 Mtr.	<b>MR</b>
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c..Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

h

Mesle

N/7

	d. No of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width Of Corridor	1.2 Mtr.	1.2 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	2 Nos.	2 Nos.	MR
	• Types	ABC	ABC	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

h

11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	NA	NA	NA
	• Head of the pump	NA	NA	NA
	• Power supply	NA	NA	NA
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage			
		NA	NA	NA
16	Provision of Lifts			

h

-N/g-

	<ul style="list-style-type: none"><li>• Pressurization of Lift Shaft</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• Pressurization of lift lobby</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• Communication in lift Car</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• Fireman's Grounding Switch</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• Lift Signage</li></ul>	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"><li>• Total area</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• Location</li></ul>	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"><li>• Detector system panel</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• Flow Switch Panel</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• PA System Panel</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• Batter backup</li></ul>	NA	NA	NA
	<ul style="list-style-type: none"><li>• Building Floor Plans</li></ul>	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/2007/1296 dated 08/05/2007 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended



Do (CC)

basehwy  
10/1/14

Signature of the Inspecting Officer

Meshr  
7/1/14

Name :- M.K. Sharma  
Designation :- A. D.O. (CC)