

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

E-mail:- [cfhq.dlfire@nic.in](mailto:cfhq.dlfire@nic.in)

Fax:- 011-23412593


No. F.6/DFS/MS/School/2014/52/122

Dated: 29/01/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Manav Sthali Junior School** located at Double Storey, New Rajendra Nagar, New Delhi-110060 is comprised of Ground floor plus two upper floors, having total 31 rooms (Including Class Rooms, Offices, Comp. Room, Sci. Lab, Multimedia Room & Store etc.) owned/occupied by the school management was inspected by the officer concerned of this department on 18.01.2014 in the presence of Sh. Ranjeet Singh (Manager) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....29/01/14.....at New Delhi.



(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Manager,  
Manav Sthali Junior School,  
Double Storey, New Rajendra Nagar, N.D-60.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110 054.

su  
Arj

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/3.

Ground Floor plus two upper floors.

INSPECTION REPORT

1. Name & address of the building : Manav Sthali Junior School, Double Storey, New
2. Type of Occupancy : Educational (School) Rajendra Ngr, N.O - 60.
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No.                      Date
5. Fire Safety directives letter No :
6. Date of inspection : 18.01.2014
7. Name of Inspecting Officer : A.D.O P.S. Sahiya
8. Name and designation of officers  
From the building side : Sh. Ranjeet Singh (Manager)
9. Year of Construction : Before 1985
10. Applicant's letter No. : MSJS/DS/15/2013 dated 25.11.2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	06 mtr	MR
	• Gate width	-	380 cms	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	MR
	• Basements	-	-	No Basement
	b. Width of staircases			
	• Upper Floor	150 cms Each	150 cms Each	MR
	• Basements	-	-	No Basement
	c. Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
	d. No. of continuous staircases to terrace	-	One	-
	e. Width of Corridor	-	300 cms	MR
	f. Door Size	-	116 cms x 200 cms	MR
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR

*(Signature)*

M/4-

M

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Two at each Floor	Provided	MR
	• Types	A.C.P, WCO <sub>2</sub>	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G. Set of 160 kVA	-
	• Hooters' Location	-	-	-
8.	MOEFA			
		Not Required	Provided	MR
9.	Public Address System			
		- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

*Reddy*

N/S Double Storey, Rajendra Nagar,  
New Delhi - 110060.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	—	—	—
		450 LPM	450 LPM	MR
		30 M	30 M	MR
		Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		10000 Ltr	10000 Ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts:</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	No Lift
		—	—	- do -
		—	—	- do -
		—	—	- do -
		—	—	- do -
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	—	—	—

*Analys*

M/6.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The school building is comprised of Ground floor plus two upper floors, having total 31 rooms, including class rooms, Offices, Comp. Room, Sci. Lab, Sports Room, Multi Media Room & Store etc. In each class students less than 45 as per letter submitted by the management vide No. MSJS/DS/2014/15 dated 18.01.2014

  
Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

