

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dfire@nic.in


No F 6 / DFS / MS / GH / 2014/ NDZ/55

Dated 15-01-2014

FIRE SAFETY CERTIFICATE

Certified that the **LA-Budha Guest House at, 3334, Gali Hari Mandir, Pahar Ganj, New Delhi** comprised of Basement (sealed), ground floor (02 guest rooms + reception + office), 1st floor to 3rd floor (04 guest rooms on each floor) and 4th floor (02 staff rooms + 02 rooms for personal use) total 14 guest rooms. The premises was inspected by the officer concerned of this department on 21-12-2013 in the presence of Mr. Rehman (Manager) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 14 guest rooms with effect from -----15/01/-----2014 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on15/01/14..... at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. The Joint. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi – 110049 w.r.t. letter No 71828/Joint.C.P./Lic(H) New Delhi 26-11-13.
2. LA-Budha Guest House at, 3334, Gali Hari Mandir, Pahar Ganj, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

2/15

INSPECTION REPORT

1. Name & address of the building : LA-BUDHA guest house, 3334, Gali Hari Mandir, Pahar Ganj, New Delhi.
2. Type of Occupancy : Residential (guest house) Basement sealed, G+4 Floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2011/17 dated 05/01/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 21/12/2013
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Mr. Rehman (Manager)
- 9 Year of Construction : 2010
10. Applicant's letter No. : 71828/Joint.C.P./Lic.(H) dated New Delhi the 26/11/13

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	NA	NA	NA
	• Gate width	1 mt	1.5 mt	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	01	01	MR
	• Upper floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	0.8 mt	1.22 mt	MR
	• Basements	NA	NA	NA
	c..Protection of exits			
	Fire check door	NA	NA	NA

mesh

N/6

	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	1 mt	1 mt	MR
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	08	10	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	YES	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 mt	30 mt	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8	MOEFA	Not required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA

2/7

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> ○ Ground Level • Discharge of main pump • Head of main pump • Number of main pumps • Jockey pump out put • Jockey pump head • Standby Pump out put • Standby Pump Head • auto Staring/Manual stopping • Pump House Access ○ Terrace level • Discharge of pump • Head of the pump • Power supply • Auto starting of pump 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	450 LPM	MR
		30 mt	30 mt	MR
		YES	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity • Draw of connection • Fire service inlet • Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		YES	Provided	MR
		3,000 ltrs	3,000 ltrs	MR

mehta

n/8

15	Exit Signage	YES	Provided	MR
16	Provision of Lifts	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NR	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2011/17 dated 05/01/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

M.K. Sharma
6/1/13

Name :- M.K. Sharma
Designation :- A. D.O. (CC)

~~Do (CP)~~

bschind
7/1/14

