

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2014/W2/43

Dated: 13/01/2014

Fire Safety Certificate

Certified that the **Green Lounge Restaurant** located on Ground floor of 39-43, Aggarwal Citi Mall, Plot no. 5, Road no. 44 Pitampura, New Delhi comprised of Basement, ground floor + three upper floors owned/occupied by **Green Lounge Restaurant** was earlier issued NOC/FSC vide this office letter No. **F6/MS/DFS/EH/2011/346** dated **21/02/2011**. The premises was re-inspected by the officers concerned of the Fire Service on **30/11/2013** in the presence of **Mr. Rajeev Nagpal (Director)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with Rule 33 of the Delhi fire Service Rules 2010 and the building/premises is fit for occupancy **Class-D Assembly** with effect from 13/01/14.....for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Issued on 13/01/14.....at New Delhi by


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Phone:-23414250

E-mail: cfowz.dlfire@nic.in

Copy to:

Mr. Rajeev Nagpal (Director)

Green Lounge Restaurant on Ground floor, 39-43, Aggarwal Citi Mall, Plot no. 5, Road no. 44 Pitampura, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

Ram Kishor

Handwritten signature

6+3 upna 11

1. Name & address of the building : Green Lounge Restaurant Ground floor, 39-43, Aggarwal Citi Mall, Plot no. 5, Road no. 44 Pitampura, New Delhi
2. Type of Occupancy : Class-D Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/EH/2011/346 dated 21/02/2011
5. Fire Safety directives letter No. : F6/MS/DFS/2005/1527 dated 19.07.2005 for the mall
6. Date of inspection : 30.11.2013
7. Name of the Inspecting Officers : Divisional Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. Rajeev Nagpal (Director)
9. Year of Construction : 2005-2006
10. Applicant's letter No. : 20-sep-2013

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

| S. No. | Minimum Standards on fire Prevention and fire safety U/R 33 | BBL Requirement | Provided at site | Remarks MR/NMR |
|--------|--|----------------------|------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | 12mtrs | 24 mtr | M.R. |
| | • Gate width | 06 mtr | Provided | M.R. |
| | • Width of internal road | As per sanction plan | Provided | M.R. |
| 2. | Number, Width, Type & Arrangement of Exits For the Mall | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | two | two | M.R. |
| | • Basement | 2 stair one ramp | Provided | M.R. |
| | b. Width of staircases | | | |
| | • Upper Floors | N.A. | N.A. | N.A. |

| | | | | |
|----|--|----------------------------|----------|----------|
| | <ul style="list-style-type: none"> Basement | N.A. | N.A. | N.A. |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door | Required | Provided | M.R. |
| | <ul style="list-style-type: none"> Pressurization | Required | Provided | M.R. |
| | d. No. of continuous staircases to terrace | N.A. | N.A. | N.A. |
| | e. Width of Corridor | Old case | Old case | Old case |
| | f. Door size | Old case | Old case | Old case |
| 3. | Compartmentation. For the Mall | | | |
| | <ul style="list-style-type: none"> Fire check door | required | Provided | M.R. |
| | <ul style="list-style-type: none"> Sealing of electrical shafts | required | Provided | M.R. |
| | <ul style="list-style-type: none"> Fire Rating of shaft door | required | Provided | M.R. |
| | <ul style="list-style-type: none"> Water Curtain | N.R. | N.R. | N.R. |
| | <ul style="list-style-type: none"> Fire Dampers | required | Provided | M.R. |
| 4. | Smoke Management System. For the Mall | | | |
| | <ul style="list-style-type: none"> Basements | required | Provided | M.R. |
| | <ul style="list-style-type: none"> Upper floors | required | Provided | M.R. |
| 5. | Fire Extinguishers for the Restaurant | | | |
| | <ul style="list-style-type: none"> Total numbers | 04 | 04 | M.R. |
| | <ul style="list-style-type: none"> Types | ABC & CO ₂ type | Provided | M.R. |
| | <ul style="list-style-type: none"> IS marking | ISI marks required | provided | M.R. |
| 6. | First-Aid Hose Rees. For Restaurant common with Mall | | | |

| | | | | |
|-----|---|--|--|------|
| | <ul style="list-style-type: none"> Total numbers on each floor | 2 | 2 provided | M.R. |
| | <ul style="list-style-type: none"> Length of hose reel hose | 30 m required | Provided | M.R. |
| | <ul style="list-style-type: none"> Nozzle diameter | 5 mm required | Provided | M.R. |
| 7. | Automatic fire detection and alarming system. | | | |
| | For Restaurant common with Mall | | | |
| | <ul style="list-style-type: none"> Type of detectors | Smoke & Heat | Provided | M.R. |
| | <ul style="list-style-type: none"> Location of Main Panel | Ground floor | Provided | M.R. |
| | <ul style="list-style-type: none"> Location of Repeater Panel | required | Provided | M.R. |
| | <ul style="list-style-type: none"> Alternate source of power | Required | Provided | M.R. |
| | <ul style="list-style-type: none"> Hooter's Location | At strategic location | Provided | M.R. |
| 8. | MOEFA | Required | Provided | M.R. |
| 9. | Public Address System. | Required | Provided | M.R. |
| 10. | Automatic Sprinkler system | For Restaurant common with Mall | For Restaurant common with Mall | |
| | <ul style="list-style-type: none"> Basement | Required | Provided | M.R. |
| | <ul style="list-style-type: none"> Upper Floor | Required | Provided | M.R. |
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | Required | Provided | M.R. |
| 11. | Internal Hydrants | | | |
| | For the Mall | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | 150 mm | Provided | M.R. |
| | <ul style="list-style-type: none"> Number of hydrants per floor | 2 | 2 | M.R. |

| | | | | |
|-----|---------------------------------|----------------------------|----------|------|
| | • Hose Box | 2 | 2 | M.R. |
| 12. | Yard Hydrants. | | | |
| | Common with Mall | | | |
| | • Total number of hydrants | 4 | 4 | M.R. |
| | • Hose Box | 4 | 4 | M.R. |
| 13. | Pumping Arrangements. | | | |
| | Common with Mall | | | |
| | Ground Level | | | |
| | ➤ Discharge of main pump | 2280 LPM | Provided | M.R. |
| | ➤ Head of Main pump | 60 mtr | Provided | M.R. |
| | ➤ Number of main pumps | One diesel Two electric | Provided | M.R. |
| | ➤ Jockey Pump out put | 180 LPM | Provided | M.R. |
| | ➤ Jockey pump head | 60 mtr | Provided | M.R. |
| | ➤ Standby pump out put | 2280 LPM | Provided | M.R. |
| | ➤ Standby pump Head | 60 mtr | Provided | M.R. |
| | ➤ Auto Starting/Manual stopping | Required | Provided | M.R. |
| | ➤ Pump Hose Access | required | Provided | M.R. |
| | Terrace level | | | |
| | ➤ Discharge of pump | 180 LPM | Provided | M.R. |
| | ➤ Head of the pump | 60 mtr | Provided | M.R. |
| | ➤ Power supply | Required | Provided | M.R. |
| | ➤ Auto Starting of pump | required | Provided | M.R. |

| | | | | |
|-----|---|-------------------------------|-------------------------|------|
| 14. | Captive Water Storage for fire fighting. | common with Mall | | |
| | Underground tank capacity | 2 lakh | Provided | M.R. |
| | ➤ Draw -off connection | Required | Provided | M.R. |
| | ➤ Fire service inlet | Required | Provided | M.R. |
| | ➤ Access to tank | Required | Provided | M.R. |
| | ➤ Overhead Tank Capacity | 20,000 ltrs | Provided | M.R. |
| 15 | Exit Signage. | Required In the Restaurant | Provided | M.R. |
| 16. | Provision of Lifts | | Common with Mall | |
| | • Pressurization of Lift Shaft | Required | Provided | M.R. |
| | • Pressurization of Lift lobby | Required | Provided | M.R. |
| | • Communication In lift Car | Required | Provided | M.R. |
| | • Fireman's Grounding Switch | Required | Provided | M.R. |
| | • Lift Signage | Required | Provided | M.R. |
| 17. | Standby power supply | Required | Provided | M.R. |
| 18. | Refuge Area | | | |
| | ➤ Total Area | N.R. | N.R. | N.R. |
| | ➤ Location | N.R. | N.R. | N.R. |
| 19. | Fire Control Room | common with Mall | common with Mall | |
| | ➤ Detector System Panel | Required | Provided | M.R. |
| | ➤ Flow Switch Panel | Required | Provided | M.R. |
| | ➤ PA system Panel | Required | Provided | M.R. |

| | | | | |
|-----|---|--|----------|------|
| | ➤ Batter backup | Required | Provided | M.R. |
| | ➤ Building Floor plans | Required | Provided | M.R. |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any: | Manually operated CO ₂ system | Provided | M.R. |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.


Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chawdhary

Name

Designation D.O. (M.N.)

Designation