

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001.

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593


No. F.6/DFS/MS/2014/SW/ 120

Dated: 29/01/14

**FIRE SAFETY CERTIFICATE**

Certified that the godown building for LPG in the name and style of **M/s Purti Alternative Fuels Pvt. Ltd** located at Khasra No-421, Village Jaffarpur Kalan, New Delhi is comprised of ground floor only was issued NOC by this department vide letter No.F.6/DFS/MS/LPG/99/1395 dated 27.10.1999 owned/ occupied by M/s Purti Alternative Fuels Pvt. Ltd. The premises was re- inspected by the officers concerned of this department on 10.01.2014 in the presence of Sh. Parveen (Godown Incharge) and found that the said godown have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the godown building / premises is fit for occupancy (LPG Godown) w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on... 29/01/14..... at New Delhi



(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. Sh. Parag Bhatia (DGM-Corporate),  
M/s Purti Alternative Fuels Pvt. Ltd.,  
46, Hill Road, Ram Nagar, Nagpur-440010.



2/6

May kindly see the letter No. Nil dated 13.12.2013 received from Sh. Parag Bhatia (DGM-Corporate) for M/s Purti Alternative Fuels Pvt. Ltd, 46, Hill Road, Ram Nagar, Nagpur-440010, regarding renewal of Fire Safety Certificate from fire safety point of view in r/o LPG Godown in the name and style of M/s Purti Alternative Fuels Pvt. Ltd located at Khasra No-421, Village Jaffarpur Kalan, New Delhi.

In this connection it is stated that the above said mentioned LPG Godown premises has been re-inspected by D.O S.K. Tomar along with A.D.O Sandeep Duggal on 10.01.2014 with the view to see the compliance of fire safety NOC/recommendation issued by this department vide letter No. F.6/DFS/MS/LPG/99/1395 dated 27.10.99. Sh. Parveen (Godown Incharge) was also present.

During the course of inspection it has been observed that the above mentioned LPG Godown is at ground floor comprised of ground floor only and approachable by fire service vehicles. Further the following fire safety arrangements required under Rule 33 are provided as under:-

1. Six fire buckets full of dry loose sand are provided at the site.
2. Two D C P type fire extinguishers having cap 10 kg each ISI mark are provided.
3. No Smoking sign boards are displayed at the site.
4. No electric wiring is passing over the godown.
5. Ventilation at ground and ceiling level with copper wire gauge.

The above mentioned fire arrangements were checked/operated randomly and found functional at the time of inspection.

In view of above this department may have no objection for renewal of Fire Safety Certificate from fire safety and means of escape point of view subject to the conditions laid down in the FSC.

Accordingly DFA is placed in the file for your kind perusal, approval and signature please.

**Divisional Officer (S.W)**

*Sandeep*  
15/1/14