

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001
Ph - 23414333 Fax - 23412593 Email - cfohq.dfire@nic.in

No. F6/DFS/MS/Banquet/2014/MDZ/96

Dated: 24/01/14

FIRE SAFETY CERTIFICATE

Certified that the Gobind Banquet, 512/2-B, Jheel Khrenja, Geeta colony Chowk, Delhi-51, comprised of ground floor owned/occupied by Gobind Banquet, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on dated 24.12.13 in the presence of Mr. Des Raj, Owner and found that the building is fit for occupancy class D 'Assembly (Banquet Hall)' with effect from 24/01/14 for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on 24/01/14 at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer

22.1.14

Copy to-

1. The Dy. Health Officer,
MCD Health Department,
Shahdara (South) Zone, 5th Floor, Karkardooma, Shahdara, Delhi
2. Shri Des Raj,
Gobind Banquet, 512/2-B,
Jheel Khrenja, Geeta colony Chowk, Delhi-51

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Gobind Banquet, 512/2-B, Jheel Khrenja, Geeta colony Chowk, Delhi-51.
 2. Building is comprised of : Ground floor
 3. Type of Occupancy : Assembly (Banquet Hall)
 4. Type of Case : New Case
 5. Details of Previous NOC : Nil
 6. Fire Safety direction letter No : F6/DFS/MS/BP/2013/2202 dated 10.09.13
 7. Date of Inspection : 24.12.13
 8. Name of the Inspecting Officers: : Suresh Singh (ADO)
 9. Name of the designation of Officer from the building side : Mr. Des Raj, Owner
 10. Year of Construction : 1976
 11. Applicant's letter No : Dated 11.09.13 & 24.09.13

| S.No | Minimum Standards on fire prevention and fire safety U/R33 | Requirement | Provided at Site | Remarks MR/NMR |
|----------------|--|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | Road width | 6 m | 17 m | MR |
| | Gate width | N.A | N.A | N.A |
| | Width of internal road | N.A | N.A | N.A |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | 2 no. | 02 no. | MR |
| | Upper Floor | N.A | N.A | N.A |
| | Basement | N.A | N.A | N.A |
| | b. Width of Staircases | 1.5 m | 1.5 m each | MR |
| | Upper Floor | N.A | N.A | N.A |
| | Basement | N.A | N.A | N.A |
| | c. Protection of exits | N.A | N.A | N.A |
| | Fire check door | N.A | N.A | N.A |
| | Pressurization | N.A | N.A | N.A |
| | e. No. of continuous staircases to terrace | N.A | N.A | N.A |
| | g. Width of Corridor | N.A | N.A | N.A |
| h. Door Size | 2 m | 3.2 m, 2 m, 2 m | MR | |
| i. No. of door | 3 no. | 3 no. | MR | |
| 3 | Compartmentation. | | | |
| | Fire check door | N.A | N.A | N.A |
| | Sealing of electrical shafts | N.A | N.A | N.A |
| | Fire rating of shaft door | N.A | N.A | N.A |
| | Water curtain | N.A | N.A | N.A |
| | Fire Dampers | N.A | N.A | N.A |
| 4 | Smoke Management System. | Ventilated | | |
| | Basement | 30a/c per hour | N.A | N.A |
| | Upper floor | 12 a/c per hour | N.A | N.A |

| | | | | |
|----|---|-----------------------|-----------------------|-----|
| 5. | Fire Extinguisher | | | |
| | Total numbers | 03 no. | 08 no. | MR |
| | types | CO ₂ & ABC | CO ₂ & ABC | MR |
| | IS marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers | 01 no. | 01 no. | MR |
| | Length of hose reel hose | 30 m | 30 m | MR |
| | Nozzle diameter | 5 mm | 5 mm | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | Type of detectors | N.A | N.A | N.A |
| | Location of main panel | N.A | N.A | N.A |
| | Location of repeater panel | N.A | N.A | N.A |
| | Alternate source of power | N.A | N.A | N.A |
| | Hooters's location | N.A | N.A | N.A |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public address System. | N.A | N.A | N.A |
| 10 | Automatic Sprinkler System. | | | |
| | basement | N.A | N.A | N.A |
| | upper floor | N.A | N.A | N.A |
| | sprinkler above false ceiling | N.A | N.A | N.A |
| 11 | Internal Hydrants | | | |
| | size of riser/down-comer | 100 mm | 100 mm | MR |
| | Number of hydrants | 01 no. | 01 no. | MR |
| | Hose Box | 01 no. | 01 no. | MR |
| 12 | Yard Hydrants. | | | |
| | Total number of hydrants | N.A | N.A | N.A |
| | Hose Box | N.A | N.A | N.A |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | N.A | N.A | N.A |
| | ➤ Discharge of main Pump | N.A | N.A | N.A |
| | ➤ Head of Main Pump | N.A | N.A | N.A |
| | ➤ Number of main pumps | N.A | N.A | N.A |
| | ➤ Jockey pump out put | N.A | N.A | N.A |
| | ➤ Jockey pump head | N.A | N.A | N.A |
| | ➤ Standby pump out put | N.A | N.A | N.A |
| | ➤ Standby pump Head | N.A | N.A | N.A |
| | ➤ Auto Starting /Manual stopping | N.A | N.A | N.A |
| | ➤ Pump House Access | N.A | N.A | N.A |
| | • Terrace Level | | | |
| | ➤ Discharge of pump | 450 LPM | 450 LPM | MR |
| | ➤ Head of the Pump | 40 m | 40 m | MR |
| | ➤ Power supply | N.A | N.A | N.A |
| | ➤ Auto Starting of pump | N.A | N.A | N.A |

| | | | | |
|----|--|---------------|--|-----|
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | Underground tank capacity | N.A | N.A | N.A |
| | Draw-off connection | N.A | N.A | N.A |
| | Fire service inlet | N.A | N.A | N.A |
| | Access to tank | N.A | N.A | N.A |
| | Overhead Tank capacity | 10,000 Liters | 10,000 Liters | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | Pressurization of Lift Shaft | N.A | N.A | N.A |
| | Pressurization of Lift lobby | N.A | N.A | N.A |
| | Communication in lift car | N.A | N.A | N.A |
| | Firemen's grounding switch | N.A | N.A | N.A |
| | Lift Signage | N.A | N.A | N.A |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | Total area | N.A | N.A | N.A |
| | Location | N.A | N.A | N.A |
| 19 | Fire Control Room | | | |
| | Detector system panel | N.A | N.A | N.A |
| | Flow switch panel | N.A | N.A | N.A |
| | PA system panel | N.A | N.A | N.A |
| | Batter backup | N.A | N.A | N.A |
| | Building Floor Plans | N.A | N.A | N.A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | Required | CO ₂ local application in electrical panel provided | MR |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh
5.1.14

Signature of the Inspecting Officer

Name Suresh Singh

Designation (ADO)

