

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

Fax:23412593 E-mail:cfohq.dlfire@nic.in

No EG(DFS/MS) School/2014/ND2/52 Dated 13-01-2014

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Senior Secondary School Khichripur, Delhi. -91. comprises of ground floor only have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03. 2011 & DFS order dates 18-4-2012 and verified by the officer concerned of Fire Service on 2-12-2013 in the presence of the Vice Principal, of the school and that the building is fit for occupancy, class B "Educational Building" with effect from 13/01/14 for a period of three year, subject to conditions printed overleaf.

Issued on 13-01-14 at New Delhi.



(DR. G.C.MISRA)
Chief Fire Officer
Delhi Fire Service
Ph. 23414333

Copy to:-

1. The Vice Principal (1st & IInd Shift)
Govt. Girls Senior Secondary School
Khichripur, Delhi. -91
2. The Joint Director Education,
(Land & Estate)
Director of Education,
Lucknow Road, Delhi-54.

Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : GGSS School, Khichripur, Delhi.
2. Building is comprised of : **Ground Floor only**
3. Type of Occupancy : Educational
4. Type of Case : Fresh
5. Details of Previous NOC : NA
6. Fire Safety direction letter No : NA
7. Date of Inspection : 02.12.2013
8. Name of the Inspecting officers : Gurmukh Singh
9. Name and designation of Officer:
from the building side : Vice Principal
10. Year of Construction : 1980
12. Applicant's letter No : GGSSS/KHP/533 dated 11.9.2013

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Dir. Edu. Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	12 Mtrs.	MR
	• Gate width	4.5Mtr	4.5 Mtr	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basement	NA	NA	NA
	B. Width of Staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basement	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA

h

	h. Door Size	1.0Mtr.	1.0 Mtr.	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.	NA		
	• Basement	NA	NA	NA
	• Upper floor	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	9 Nos.	15Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	Required	Provided	MR
6	First-aid-Hose Reels.			
	• Total numbers at ground floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA	NA	NA
	• Basement	NA	NA	NA
	• upper floor (1 st floor)	NA	NA	NA
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	NA	NA	NA
	• size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA.	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	NA	NA.	NA
	• Hose Box	NA	NA	NA

13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA		
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

h

M/9

20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular of Director Education, GNCTD in the light of office order No.F2/DFS/HQRS/300 dated 18-04-2012 it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Handwritten Signature]

Signature of the Inspecting Officer

Name *Guramkh Singh*
 Designation *DO*

DO (E.)

Submitted for approval please.

By CFO (NDZ)

[Handwritten Signature]

2/1

11/1/14



CFO [Signature]

