

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/GH/2014/70

Dated: 17/01/2014

FIRE SAFETY CERTIFICATE

Certified that the Eternity, (a unit of Bright Hospitality) B-40, Vishal Enclave, New Delhi comprised of Basement +Ground floor + three upper floors, owned / occupied by Eternity was earlier issued NOC / FSC vide this office letter No. F.6/DFS/MS/GH/2011/171 dated 28.01.2013. The premises was re-inspected by the officers concerned of the fire service on 15.12.2013 in the presence of Sh. Manmeet Singh and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have, therefore, deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy (Residential) (Group-A-1 (i) with effect from 17.01.2014 for a period of five years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules,2010.

Conditions for validity of Fire Safety Certificate :-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

Issued on...17.01.2014.....at New Delhi by



Santokh Singh
Chief Fire Officer
Delhi Fire Service

E-mail : cfowzr.dlfire@nic.in
Phone : 011-23414250

Copy to:

1. Sh. Manmeet Singh
Eternity, B-40, Vishal Enclave, New Delhi-110027
2. Joint Commissioner of Police (Lic) 1st floor P.S., Defence, Colony, New Delhi



N/3

1. Name & address of the building : Eternity, B-40, Vishal Enclave, New Delhi
2. Type of Occupancy : Group-A-1 (i) Residential
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2011/171 dated 28/01/2011
5. Fire Safety directives letter No. : nil
6. Date of inspection : 15.12.2013
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers
 From the building side : Sh. Manmeet Singh
9. Year of Construction : 2008
10. Applicant's letter No. : 63823/jontC.P./Lic/(H) dated 21.10.13

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12mtrs	Provided	M.R.
	• Gate width	N.A.	N.A.	N.A.
	• Width of internal road	N.A.	N.A.	N.A.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Old case	1	MR
	• Basement	Old case	2	MR
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case
	• Basement	Old case	Old case	Old case

r/h

	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	One	Provided	MR
	e. Width of Corridor	Old case	Old case	Old case
	f. Door size	Old case	Old case	Old case
3.	Compartmentation.			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	N.A.	N.A.	N.A.
	• Fire Rating of shaft door	N.A.	N.A.	N.A.
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4.	Smoke Management System.			
	• Basements	Required	Provided	M.R.
	• Upper floors	Required	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	12	16 provided	M.R.
	• Types	ABC & CO ₂ type	Provided	M.R.
	• IS marking	ISI marks	provided	M.R.
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	1	one	M.R.
	• Length of hose reel hose	30 m	Provided	M.R.

N/5

N-7

	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Location of Main Panel 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Location of Repeater Panel 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Alternate source of power 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Hooter's Location 	N.A.	N.A.	N.A.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	Required	Provided	MR
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Upper Floor 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N.A.	N.A.	N.A.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Number of hydrants per floor 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Hose Box 	N.R.	N.R.	N.R.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N.R	N.R.	N.R.
	<ul style="list-style-type: none"> Hose Box 	N.R	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	<ul style="list-style-type: none"> ➤ Discharge of main pump 	N.R	N.R	N.R

~~NA~~ N-6

	➤ Head of Main pump	N.R	N.R	N.R
	➤ Number of main pumps	N.R	N.R	N.R
	➤ Jockey Pump out put	N.R	N.R	N.R
	➤ Jockey pump head	N.R	N.R	N.R
	➤ Standby pump out put	N.R	N.R	N.R
	➤ Standby pump Head	N.R	N.R	N.R
	➤ Auto Starting/Manual stopping	N.R	N.R	N.R
	➤ Pump Hose Access	N.R	N.R	N.R
	Terrace level			
	➤ Discharge of pump	450 LPM & 180 LPM	provided	M.R.
	➤ Head of the pump	50 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	➤ Overhead Tank Capacity	10,000	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.

16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A	N.R	N.R
	• Pressurization of Lift lobby	N.A	N.R	N.R
	• Communication In lift Car	N.A	N.R	N.R
	• Fireman's Grounding Switch	N.A	N.R	N.R
	• Lift Signage	N.A	N.R	N.R
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standard of fire prevention and fire safety measure as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2011/171 dated 28/01/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

28.10


28/12

Signature of the Inspection Officer

Name

Sunil Chawdhary

Designation

D.O.

Signature of the Inspection Officer

Name

Designation